

Notice of Determination

Appendix D

TO: Office of Land Use and Climate Innovation
 State Clearinghouse
 P.O. Box 3044, Room 113
 Sacramento, CA 95812-3044

FROM: Central Valley Flood Protection Board (Board)
 3310 El Camino Avenue, Suite 170
 Sacramento, CA 95821
 Angela Nguyen-Tan, (916) 837-3717
 Angela.Nguyen-Tan@cvflood.ca.gov

SUBJECT: Filing of Notice of Determination pursuant to Public Resources Code Section 21108.

State Clearinghouse Number (SCH No.): 2009112025

Project Title: Permit No. 20057 American River Watershed Common Features Project / Natomas Post-Authorization Change Report / Natomas Levee Improvement Program / Landside Improvements Project Phase 4b: 1321 Garden Highway Sewer Line and Accessories Replacements

Project Applicant: Sierra Health Foundation

Lead Agency/Address: Sacramento Area Flood Control Agency, 1007 7th Street, 7th Floor, Sacramento, CA 95814

Lead Agency Contact Person: John Bassett, Director of Engineering, (916) 874-7606, bassetj@saccounty.net

Project Location/City/County: The project is located at 1321 Garden Highway, Sacramento, CA, 95833, at approximately 38.603787°N, 121.514112°W, Levee Mile 18.10, Reclamation District 1000, Unit No. 1, Sacramento River, Sacramento County.

Project Description: Approval of Permit No. 20057 under California Code of Regulations, Title 23, Article 3, Section 6, for work within an adopted plan of flood control: To relocate 108 linear feet of an existing 6-inch-diameter sewer pipeline (Baord Permit No. 16083) that crosses the levee at 1321 Garden Highway, Sacramento. The new sewer line will be a 6-inch-diameter American Water Works Association (AWWA) C200 steel pipe, with an invert elevation of 36.35 feet and located 3.6 feet below the crown of the levee. The existing manhole at the waterside connection point will be replaced with a new 48-inch MH-03 manhole in compliance with Sacramento Area Sewer District standards. A new 6-inch gate valve and valve box will be installed along the alignment near the new manhole, and a marker bollard will be installed in the vicinity of the new manhole. This work is associated with Natomas Basin Civil Works Project, Reach A construction (Phase 4b Project). The existing 6-inch diameter sewer line was authorized under Board Permit No. 16083, issued to Sierra Health Foundation on March 8, 1994.

This is to advise that the Board, as the **Responsible Agency**, approved the above-described project on 4/14/2026 and made the following determinations regarding the above-described project:

1. The project [will / will not] have a significant effect on the environment (This determination is limited to effects within the Board’s permitting jurisdiction as a responsible agency).
2. [An Environmental Impact Report (EIR) / A Mitigated Negative Declaration] was prepared by the lead agency for the original project.
3. Additional mitigation measures [were / were not] made a condition of the Board’s approval of the project.
4. A Mitigation Monitoring and Reporting Plan [was / was not] adopted by the Board for this project
5. A Statement of Overriding Considerations [was / was not] adopted by the Board for this project.
6. Findings [were / were not] made by the Board pursuant to the provisions of CEQA.

Responsible Agency Statement: The EIR prepared by the Lead agency for the project is available to the public at the Lead agency’s office listed above. The Board’s administrative record related to the encroachment permit is available for public review at the Board’s office.

| | | |
|-----------|-------------------------------|-----------|
| | <i>Chris Lief</i> | 4/14/2026 |
| Signature | Chris Lief, Executive Officer | Date |

Authority cited: Sections 21083, Public Resources Code.
 Reference: Sections 21100-21174, Public Resources Code.