

Appendix I

Hydraulic Model Evaluation



CITY OF SANTA ANA

TECHNICAL MEMORANDUM

**HYDRAULIC MODEL EVALUATION
FOR
THE VILLAGE PROJECT**

Final

June 2024

Prepared For:



Prepared By:





June 26, 2024

City of Santa Ana
215 S Center Street
Santa Ana, CA 92703

Attention: Christine Le, Assistant Engineer

Subject: Hydraulic Model Evaluation for the Village Project

The objective of this technical memorandum is to present the findings of the hydraulic modeling analysis conducted for the Village Project development (project). The project is located at the northeast corner of Bear Street and Sunflower Avenue. The boundaries of the project encompass the areas bordered by South Plaza Drive to the east, Bear Street to the west, the multi-family housing communities to the north, and Sunflower Drive to the south. **Figure 1** illustrates the existing water infrastructure and the location of the project. The hydraulic analysis was performed to determine the required size for the water mains to serve the development and assess the impacts of the development on the system operations.

1.0 SUMMARY OF RESULTS

The hydraulic analysis was performed for maximum day demands, peak hour demands, and maximum day demands plus a 3,000 gallons per minute (gpm) fire flow to determine the impacts on the existing system and to recommend system improvements for the project. The hydraulic analysis indicated only minor impacts, summarized as follows:

- During peak hour demands only minor pressure reductions of 2.8 pound per square inch (psi) were observed and no major impacts to the existing system pipelines were evident.
- During maximum day demands plus 3,000 gpm fire flow, the existing system is capable of providing pressures above 20 psi and pipeline velocities under 7 feet per second (fps).
- An extended-period simulation (EPS) scenario was performed to determine if the project demands impacted the existing system operations. The analysis indicated no major impacts or deficiencies were caused by the project.

2.0 HYDRAULIC MODELING ASSUMPTIONS

The City's existing hydraulic model (WaterCAD) was used to simulate steady-state and extended-period simulations (EPS) to evaluate the development impacts. In order to reflect the recent water conservation efforts, the system water demands were updated as follows:

- Average Day Demand (ADD): 30.2 MGD = 20,947 gpm
- Maximum Day Demand (MDD): 60.3 MGD = 41,894 gpm
- Peak Hour Demand (PHD): 105.6 MGD = 73,315 gpm

These values are consistent with the annual demand documented in 2020 Urban Water Management Plan (2020 UWMP) and the peaking factors for MDD and PHD in Santa Ana Design Guidelines.

To account for the recent operational changes and newly constructed facilities, the hydraulic water model was updated as follows:

- Groundwater Wells 16, 22, 32, 42, and 43 were inactive.
- Interconnections SA-3, SA-4, SA-5, and SA-7 were inactive.
- Pump curves were updated based on the pump test reports provided by Santa Ana staff in December 2022.
- The storage reservoir levels were updated to the Tank Operational Ranges provided by Santa Staff in January 2023.
- The operational controls of reservoir pumping stations were updated to the SCADA- Reservoir Related Setpoints provided by Santa Ana staff in January 2023 ([Appendix A](#)).

The status of the water system wells, pump stations, tanks, interconnections, and pressure regulating stations in the hydraulic model is documented on [Table 1](#).

3.0 ANALYSIS CRITERIA AND ASSUMPTIONS

The water system performance criteria used for the project were obtained from the City of Santa Ana Design Guidelines, which were published in November 2020. [Table 2](#) documents the development summary, peaking factors, unit factors, required fire flows, pipeline performance criteria, and system pressure criteria.

The project's fire flow requirement of 3,000 gpm at 20 psi for a duration of 3 hours was assumed based on the requirements provided in City's 2017 Water Master Plan. The actual fire flow requirements will be determined by the Orange County Fire Authority (OCFA) and may affect the final design requirements.

The demands of the development were estimated based on the project land use areas and the unit factors found in the City's criteria. The project land use area details are provided in [Appendix B](#) for reference purposes. Average occupants per unit value was set 2.41 capita/du based on Santa Ana 2045 General Plan's persons per household assumptions. [Table 3](#) documents the existing and estimated demands for land use types within the project.

The following project demands were estimated and incorporated into the hydraulic model:

- Average Day Demand (ADD): 345 gpm
- Maximum Day Demand (MDD): 690 gpm
- Peak Hour Demand (PHD): 1,207 gpm

4.0 STEADY STATE HYDRAULIC ANALYSIS SCENARIOS

The hydraulic analysis will be performed for 3 scenarios to determine the recommended pipelines for the development of the Village Project:

- Scenario 1: Maximum Day Demands
- Scenario 2: Peak Hour Demands
- Scenario 3: Maximum Day Demands + 3,000 gpm fire flow requirement.

5.0 STEADY STATE HYDRAULIC ANALYSIS RESULTS

Steady-state evaluations during maximum day demands (MDD), peak hour demands (PHD), and maximum day demands plus fire flow (MDD+FF) were performed for each scenario to identify deficiencies caused by the project.

Scenario 1: Maximum Day Demands

According to the hydraulic analysis, the service pressures drop approximately 0.5 psi during the maximum day demand scenario with the addition of the project, decreasing from 92.0 psi (existing) to 91.5 psi (buildout). However, both the pre- and post-development service pressures remain within the City's criteria, maintaining a minimum pressure of 40 psi. [Figure 2](#) documents the existing and buildout system pressures under maximum day demands.

Scenario 2: Peak Hour Demands

During this scenario, the service pressures drop approximately 2.8 psi with the addition of the project, dropping from the existing 82.7 psi to 79.9 psi at buildout. Despite this drop, the minimum pressure requirement of 40 psi set by City's criteria is still satisfied both before and after the project development. Additionally, the hydraulic analysis indicates that during the peak hour demand scenario, the pipeline velocities will maintain the City's criteria, which allows for a maximum velocity of 5 fps under peak hour demands. [Figure 2](#) documents the system pressures and pipeline velocities observed during the peak hour demand (PHD) scenario.

Scenario 3: Maximum Day Demands + 3,000 gpm Fire Flow

The hydraulic analysis indicates that during this scenario, the system will maintain fire flow residual pressures above 20 psi and pipeline velocities under 7 fps. The critical fire flow location is observed at the 12-inch pipe segment along Bear Street and the pipeline velocity during a fire flow event will be approximately 6.2 fps with a residual pressure of 86.8 psi. The fire flow results, and the pipeline velocities are documented in [Figure 3](#).

6.0 WATER SYSTEM OPERATIONS EPS HYDRAULIC ANALYSIS SCENARIOS

In order to assess the overall system impact of adding the Village development to the domestic water system, City staff requested the extended-period simulation (EPS) scenarios to be conducted under the maximum day demand (MDD) conditions. The scenarios are as follows:

- Existing: Existing operations
- Buildout: Existing operations plus the Village Project

7.0 WATER SYSTEM OPERATIONS EPS HYDRAULIC ANALYSIS RESULTS

The hydraulic analysis was performed for buildout scenario and compared to the existing operations. The results of the EPS analysis provide valuable insights into the system's performance with the addition of the project.

The EPS analysis results/impacts for buildout condition are summarized in [Table 4](#). This table documents the change in pressures and increase or decrease of production at each of the wells, booster stations, pressure reducing valves and turnouts (interconnections). The EPS exhibits for each facility are provided in [Appendix C](#).

The hydraulic analysis indicates that the development of the project will not have major impacts on the existing system operations. The EPS modeled results are documented as follows:

Development's Demand and Pressure

The project adds an additional demand of 690 gpm to the system's maximum day demand. The average pressure in the MDD EPS scenario indicated a drop of approximately 0.6 psi, decreasing from 91.5 psi (existing) to 90.8 psi (buildout).

Groundwater Wells

Well-37 production increased from 1,345 gpm (existing) to 1,435 gpm (buildout), resulting in additional production of 90 gpm flow. Well-41 production increased from 536 gpm (existing) to 628 gpm (buildout), resulting in additional production of 93 gpm flow.

Booster Stations

South Booster Station outflow increased from 964 gpm (existing) to 1,356 gpm (buildout), resulting in additional outflow of 392 gpm.

Pressure Sustaining Valves

There was no significant impact to pressure sustaining valves during the EPS simulation with the addition of the project.

8.0 ANALYSIS RECOMMENDATION SUMMARY

The hydraulic analysis indicates that with the addition of the Village Project, the existing system does not require pipeline improvements based on the performance criteria documented on [Table 2](#). During maximum day demands plus 3,000 gpm fire flow scenario, the residual pressures maintain above 20 psi, and the highest pipeline velocity of 6.2 fps is observed at the 12-inch pipe segment along Bear Street. During peak hour demands, the pipelines velocities remain under City's velocity criteria of 5 fps, and the service pressures indicate 79.5 psi which is only approximately 2.8 psi decrease from the existing conditions.

The extended-period simulation results indicated that with the addition of the Village Project, there were no major impacts to the system operations as documented on [Table 4](#).


Sincerely,

AKEL ENGINEERING GROUP, INC.



Tony Akel, P.E.
Principal

FIGURES



Legend

Development Area

Inactive System

- Wells
- Interconnections

Existing System

- Tanks
- Wells
- Stations
- PRVs
- Interconnections

Pipelines

Pressure Zone

- High Zone
- Low Zone


Rivers

- Santa Ana River
- Santiago Creek

**Figure 1
The Village Project
Site Map**

Hydraulic Model Evaluation
For The Village Project
City Of Santa Ana





Legend

Hydraulic Analysis

1.2ft/s PHD Velocity

● Pressure Junction

— Proposed Private Pipelines

Existing System

Pipelines by Diameter

— 6" or Smaller

— 8" - 10"


— 12" or Larger

■ Development Area

Figure 2 MDD and PHD Steady State

Hydraulic Model Evaluation
For The Village Project
City Of Santa Ana





Legend

Hydraulic Analysis

1.2ft/s Velocity at 3,000 gpm FF

● Fire Flow Junction

— Proposed Private Pipelines

Existing System

Pipelines by Diameter

— 6" or Smaller

— 8" - 10"

— 12" or Larger

■ Development Area

Note:

- Modeled Scenario: MDD + Fire
- Velocity Constraint: 7 fps
- Pressure Constraint: 20 psi
- Design Fire Flow: 3,000 gpm

Figure 3 3,000 gpm Fire Flow Analysis Results

Hydraulic Model Evaluation
For The Village Project
City Of Santa Ana



TABLES

Table 1 Modeled Facility Inventory

Hydraulic Model Evaluation for The Village Project
City of Santa Ana

Facility	Pressure Zone	Status	Facility	Pressure Zone	Status
Groundwater Wells			Pump Stations		
Well 16	Low	Inactive	Cambridge	High	Active
Well 18	Low	Active	Crook	High	Active
Well 20	Low	Active	East	Low	Active
Well 21	Low	Active	John Garthe	Low	Active
Well 22	High	Inactive	South	Low	Active
Well 24	Low	Active	Walnut	Low	Active
Well 26	Low	Active	West	Low	Active
Well 27	High	Active	Storage Tanks		
Well 28	High	Active	Cambridge	High	Active
Well 29	Low	Active	Crook	High	Active
Well 30	Low	Active	East	Low	Active
Well 31	Low	Active	Elevated	Low	Active
Well 32	Low	Inactive	John Garthe	Low	Active
Well 33	Low	Active	South	Low	Active
Well 34	Low	Active	Walnut	Low	Active
Well 35	Low	Active	West	Low	Active
Well 36	Low	Active	Interconnections		
Well 37	Low	Active	SA-1	Low	Active
Well 38	High	Active	SA-2	Low	Active
Well 39	Low	Active	SA-3	Low	Inactive
Well 40	High	Active	SA-4	Low	Inactive
Well 41	Low	Active	SA-5	Low	Inactive
Well 42	Low	Inactive	SA-6	High	Active
Well 43	Low	Inactive	SA-7	Low	Inactive
Pressure Regulating Stations					
PRV-1	Low	Active	PRV-3	Low	Active
PRV-2	Low	Active	PRV-4	Low	Active

Notes:

1. The modeled elements are validated by Santa Ana Staff in December 2022.

Table 2 The Village Project Development Hydraulic Analysis Criteria

Hydraulic Model Evaluation for the Village Project


City of Santa Ana

No.	Item	Item Description		Comments
1.1	Development Summary	Existing Land Use: Retail/Commercial	Gross Land Area: 17 ac	Project Area extracted from The Village Specific Plan - Draft August 2023, Table 3-1.
		Proposed Land Use: Mixed Use (Residential, Commercial, Office)	Residential - 1,583 du Commercial - 80,000 sf Office - 300,000 sf Open Space (Public) - 158,300 sf Landscape - 90,000 sf	Development information extracted from The Village Specific Plan Draft August 2023, Table 3-1. Landscape area received from City staff (3/28/2024).
1.2	Project Demands Estimates	Peaking Factors: Average Day Demand Maximum Day Demand (2.0 x ADD) Peak Hour Demand (3.5 x ADD)	Unit Factors: 1. MFR: 120 gpd/capita (Occupants per Unit: 2.41) 2. Commercial: 2,500 gpd/ac 3. Open Space/Landscape: 3,000 gpd/ac	Water demand factors and peaking factors extracted from Design Guidelines and Standard Drawings for Water and Sewer Facilities, City of Santa Ana, November 2020. Average Occupants per unit value extracted from Santa Ana 2045 General Plan, persons per household assumptions.
1.3	Fire Flows	Minimum Required Fire Flow and Duration	3,000 gpm at 20 psi residual for a duration of 3 hours	It should be noted that, at the time of this hydraulic modeling effort, the project-specific fire flow requirements were not yet available. Therefore, infrastructure recommendations are based on the fire flow requirements based on land use provided in City's 2017 Water Master Plan. The actual fire flow requirements will be determined by the Orange County Fire Authority (OCFA) and may affect the final design requirements.
1.4	Pipeline Criteria		PHD Max Velocity: 5 fps MDD +FF Max Velocity: 7 fps	Extracted from City of Santa Ana Design Guidelines Published Nov. 2020
1.5	Pressure Criteria		Maximum static pressure: 100 psi. Minimum residual pressure: 40 psi at PHD. Minimum residual pressure: 20 psi at MDD + FF	Extracted from City of Santa Ana Design Guidelines Published Nov. 2020

Table 3 Domestic Water Demands

Hydraulic Model Evaluation for the Village Project
City of Santa Ana

Classification	Development Information									Model Inputs ³		
	Existing Units ¹	Proposed Units ¹	Average Occupants per Unit ²	Water Duty Factor ³	Existing Daily Water Demand	Proposed Daily Water Demand	Existing Annual Water Demand	Proposed Annual Water Demand	Change in Annual Demand (AFY)	ADD	MDD	PHD
					(gpd)	(gpd)	(AFY)	(AFY)	(AFY)	(gpm)	(gpm)	(gpm)
Residential Demands												
Residential	0	1,583 du	2.41 capita/du	120 gpd/capita	0	457,804	0	513	513	318	636	1,113
Non-Residential Demands												
Commercial	13.2 ac	80,000 sf		2,500 gpd/ac	33,000	4,591	37	5	-32	3	6	11
Office	0	300,000 sf		2,500 gpd/ac	0	17,218	0	19	19	12	24	42
Open Space (Public)	0.5 ac	3.6 ac		3,000 gpd/ac	1,500	10,902	2	12	11	8	15	26
Landscape Area	0	2.1 ac		3,000 gpd/ac	0	6,198	0	7	7	4	9	15
Total					34,500	496,713	39	556	518	345	690	1,207

Note:  4/4/2024

1. Data extracted from The Village Santa Ana Specific Draft Plan (August 2023), Table 1-1 and Table 3-1, and the project information received from City staff (3/28/2024).

2. Average occupants per unit value extracted from Santa Ana 2045 General Plan, persons per household assumptions.

3. Water duty factors and peaking factors based on Design Guidelines, City of Santa Ana, November 2020.

Table 4 Water Facility Impacts
Hydraulic Model Evaluation for the The Village Project
City of Santa Ana

Facility ID	Pressure Zone	Data Type	Existing EPS	Buildout EPS	
1	2	3	4	Results 7	Changes 8
The Village Development			(gpm)	(gpm)	(gpm)
The Village	Low	Demand	0	690	+690
The Village	Low	Pressure (psi)	91.5	90.8	-0.6
Groundwater Wells			(gpm)	(gpm)	(gpm)
Well 31	Low	Outflow	1,286	1,288	+3
Well 35	Low	Outflow	1,916	1,929	+13
Well 37	Low	Outflow	1,345	1,435	+90
Well 41	Low	Outflow	536	628	+93
Well 28	High	Outflow	2,497	2,496	0
Well 38	High	Outflow	0	0	0
Well 40	High	Outflow	0	0	0
Booster Stations			(gpm)	(gpm)	(gpm)
John Garthe	Low	Outflow	7,403	7,449	+46
Walnut	Low	Outflow	5,133	5,122	-11
East	Low	Outflow	2,446	2,453	+7
West	Low	Outflow	5,983	6,036	+52
South	Low	Outflow	964	1,356	+392
Cambridge	High	Outflow	1	1	0
Crook	High	Outflow	0	0	0

APPENDICES

Appendix A

City of Santa Ana
SCADA – Reservoir Related Set Points

City of Santa Ana

SCADA – Reservoir Related Setpoints

Cambridge

RTU-4 - Cambridge Reservoir and Pump Station					7 : 51 : 59 Jan/11/2023 8:45:09 AM			
	RUN STAT.	SWITCH POS.	FAIL	STAGE SEL.				
Booster 1 (75 HP)	OFF	AUTO	NORMAL	1				
Booster 2 (75 HP)	OFF	AUTO	NORMAL	3				
Booster 3 (75 HP)	OFF	AUTO	NORMAL	2				
Well 38 (350 HP)	OFF	OFF	NORMAL					
					START		STOP	
Stage 1					55	Psi	85	Psi
Stage 2					45	Psi	67.9	Psi
Stage 3					40	Psi	65.9	Psi
Well 38					45	Psi	50	Psi
VFD					55	Psi		
ANALOG VALUES		STATUS / CONTROL		SETPOINTS Bypass Valve				
M.O.L 16'		Automatic Control		Pressure Setpoint				
Res. Level	5 FT	Bypass Valve		Open	<	10	FT	
Disch. Flow	0 CFS	BPV Time Status		Close	>	12	FT	
Bypass Flow	.8 CFS	Mid-Peak Tou Status		Start Time		255	(Military Time)	
System Press	66.6 PSI	On Peak TOU Status		Stop Time		640	(Military Time)	
Well 38 Flow	0 CFS	ENABLE MANUAL SPEED CONTROL		Station Controls & TOU Controls				
Well 38 Press	67.7 PSI	SCADA		Mid-Peak TOU Begin	999	End	999 MT	
CL2 Day Tank	-12.8 GAL	MANUAL SPEED SETTING		On Peak TOU Begin	999	End	999 MT	
CL2 Residual	.00 PPM	7.5 %		Low Level Shutdown	3			
AUTO START/STOP				Low Level Reset	4.99			
LOCAL				High Level Shutdown	16.4			
				High Level Reset	16			
				Booster Pump Timer	3600			

Crooke

RTU-3 - Crooke Reservoir and Pump Station					7 : 51 : 59 Jan/11/2023 8:45:09 AM		
		RUN STAT.	SWITCH POS.	FAIL	STAGE SEL.		
Booster 1	(150HP)	OFF	AUTO	NORMAL	1	Stage 1	77 PSI 115 PSI
Booster 2	(150HP)	OFF	AUTO	NORMAL	2	Stage 2	45 PSI 98 PSI
Booster 3	(150HP)	OFF	AUTO	NORMAL	3	Stage 3	40 PSI 95 PSI
Well 27	(300HP)	OFF	MANUAL	NORMAL		Well 27	0 FT 0 FT
Well 28	(350HP)	OFF	MANUAL	NORMAL		Maximum Operating Level is 18 Feet	
Well 27 NaClO Tank Level			126	Gallons		Well 28	0 PSI 0 PSI
Well 28 NaClO Tank Level			223	Gallons		VFD	83 PSI
						Fixed Speed	80 %
ANALOG VALUES		STATUS / CONTROL		BYPASS VALVE SETPOINTS			
Bypass Flow	0 CFS	Automatic Control	AUTO	Pressure Setpoint	85	PSI	
Res. Level	12.1 Ft	Bypass Valve	CLOSED	Open	< 7	FT	
Disch. Flow	0 CFS	BPV TOU Status	INACTIVE	Close	> 12	FT	
System Press.	87 PSI	Mid-Peak TOU Status	INACTIVE	Start Time	999	(Military Time)	
Well 27 Flow	0 CFS	On-Peak TOU Status	INACTIVE	Stop Time	999	(Military Time)	
Well 28 Press.	82.8 PSI	Turnover Sequence	OFF	T.O.U. SETPOINTS			
Well 28 Flow	0 CFS	Auto Start/Stop	LOCAL	Mid-Peak TOU Begin	999	End	999
CL2 Residual	1.07 PPM	Excessive Starts SP	5	On Peak TOU Begin	999	End	999
		Starts This Hour	0	Boosters TOU Override	45	PSI	(Military Time)
				Well 27 TOU Override	3	Ft	
				Low Level Shutdown	3	Ft	
				Low Level Reset	4	Ft	

East

RTU-5 - East Reservoir and Pump Station				7 : 52 : 59 Jan/11/2023 8:45:09 AM										
		RUN STATUS	SWITCH POSITION	SCADA READY										
Booster 1 (125 HP)	OFF	AUTO	YES											
Booster 2 (125 HP)	OFF	AUTO	YES											
Well 26 (200 HP)	OFF	OFF	NO											
(Bowl Depth - 250 feet/Static Sounding - 136 feet/Running Sounding - 220 feet)														
ANALOG VALUES					BYPASS VALVE SETPOINTS									
System Pressure	77.7	PSI	Reservoir Level	12.4	FT									
Discharge Flow	0	CFS	Well 26 Flow	0	GPM	Bypass PID Pressure SP	78							
VFD #1 Speed	0	%	NaClO VFD Speed	0	Hz	Open <	18.5	FT AND >	70	PSI				
VFD #2 Speed	0	%	Prelube Flow	0	GPM	Close >	24	FT OR <	65	PSI				
Bypass Flow	0	CFS	Well 26 NaClO Level	300.5	Gallons	Start Time	100	Stop Time	500					
Bypass Valve Position	0	% Open	Residual	.06	PPM	BPV Fill Control	ENABLE	Open Command	●					
					BPV Fill Status		INACTIVE	Close Command	●					
STATUS / CONTROL					TIME OF USE SETPOINTS									
Pressure Control Status	ACTIVE		Well 26 NaClO VFD Ready	●	Well 26 TOU Status						INACTIVE			
Booster Enable/Disable	ENABLE		Well 26 NaClO VFD Running	●	Well 26 TOU Start Time						999	Stop Time	999	
Relief Valve Position	CLOSED		Well 26 Prelube Ready	●	Well 26 TOU Override Level SP						3	FT		
NaClO VFD Switch Pos.	AUTO		Well 26 Prelube Satisfied	●	Well 26 TOU Override Stop Level SP						21	FT		
Pressure Control Switch Pos.	PID		Well 26 Prelube In Test Mode	●										
VFD Lead/Lag Switch Pos.	SCADA		BPV Fully Open	●	MISCELLANEOUS SETPOINTS									
Lead VFD	VFD #2		BPV Fully Closed	●	Min. Res. Level to Start Pumps						5	FT		
Lead/Lag Runtime Ratio	50	%				Reservoir Level Hi Hi Alarm SP						28	FT	
						Reservoir Level Lo Lo Alarm SP						4.5	FT	



Garthe

RTU-2 - John Garthe Reservoir					7 : 52 : 59 Jan/11/2023 8:45:09 AM	
	RUN STAT.	AVAILABLE	FAIL	SW. POS.		
Booster #1 (100 HP)	OFF	IN-SERVICE	NORMAL	AUTO	Start Setpoint 59 PSI	
Booster #2 (150 HP) VFD	RUN	IN-SERVICE	NORMAL	AUTO	Maintain Setpoint 62 PSI	
Booster #3 (150 HP) VFD	OFF	IN-SERVICE	NORMAL	AUTO		
Booster #4 (200 HP)	RUN	IN-SERVICE	NORMAL	AUTO	START STOP	
Booster #5 (250 HP)	OFF	IN-SERVICE	NORMAL	AUTO	Well Stage 1 22 Ft 24 Ft	
Well #39 (250 HP)	OFF	2	NORMAL	AUTO	Well Stage 2 21.5 Ft 23.5 Ft	
Well #18 (150 HP)	RUN	1	NORMAL	AUTO	M.O.L 25'	
Well #36 (250 HP)	RUN	1	NORMAL	AUTO	TOU Low PSI	
Well #24 (150 HP)	OFF	2	NORMAL	AUTO	Override Setpoint 45 PSI	
ANALOG VALUES			STATUS / CONTROL		SETPOINTS	
Bypass Flow 0 CFS	Automatic Control AUTO		Bypass Valve Enable 18 (AND) 65			
Res. Level 21.7 Ft	Bypass Valve CLOSED		Bypass Valve Disable 4.7 (OR) 60			
Disch. Flow 11.3 CFS	Mid-Peak TOU Status INACTIVE		Bypass Ctrl Time Start 999 Stop 999			
System Press 64.1 PSI	On Peak TOU Status INACTIVE					
SA-1 Flow 0 CFS	MWD Plug Valve UNKNOWN		T.O.U. SETPOINTS			
CL2 Residual 0.69 PPM	Well 24 Auto Ctrl AUTO		Mid- Peak TOU Begin 999 End 999 MT			
W36 CL2 Level 352.3 GAL	BPV TOU Status ACTIVE		On Peak TOU Begin 999 End 999 MT			
W39 CL2 Level 398 GAL	Engine Ctrl ACTIVE		TOU Override 2.5			
	W-24 MOV Open		Low Level Shutdown 2 Reset 7 Ft			
	W-24 MOV Closed		Engine Ctrl Start Time 999 Stop 999 MT			

Walnut

RTU-1A - Walnut Reservoir and Pump Station										
						7 : 52 : 59 Jan/11/2023 8:45:09 AM				
RUN STAT. SW. POS. FAIL AVAILABLE SPD						STATION & VFD STATUS/CONTROL				
Booster 1 (200 HP) VFD	OFF	AUTO	NORMAL	IN-SERVICE	0 %	Disch. Pressure Setpoint	67.5	PSI		
Booster 2 (200 HP) VFD	RUN	AUTO	NORMAL	IN-SERVICE	97 %	Disch. Pressure Deadband	1.25			
Booster 3 (200 HP)	OFF	AUTO	NORMAL	IN-SERVICE		Pump Stage Delay	200			
Booster 4 (150 HP)	OFF	AUTO	NORMAL	IN-SERVICE		Pump Auto Rotat. Max Flow	3	CFS		
Booster 5 (100 HP)	OFF	AUTO	NORMAL	IN-SERVICE		Pump Auto Rotat. Start Time	230			
						Pump Auto Rotat. Stop Time	530			
WELLS STAGE SELECTION						BYPASS VALVE SET POINTS				
Well 16 (150 HP)						BPV TOU Status	OFF			
Well 29 (200 HP)	RUN	AUTO	NORMAL	IN-SERVICE		Bypass Valve	OPEN			
Well 33 (300 HP)	OFF	AUTO	NORMAL			SA-2 Press	0	PSI		
ANALOG VALUES						STATUS / CONTROL				
Bypass Flow	0	CFS				TOU Status	OFF			
Res. Level	15	FT				Low Press Override SP	45	PSI		
Disch. Flow	5.5	CFS				Bypass Ctrl Enable	DISABLED			
System Press	67.2	PSI				WELL VALVE STATUS				
CL2 Day Tank	765	GAL				Open Stat.	SW. Pos.	FAIL	AVAILABLE	
Residual	1.01	PPM				Well 16 Res. Valve	CLOSED	LOCAL	ALARM	OUT-SERVICE
WELL SETPOINTS						Well 16 Waste Valve	CLOSED	LOCAL	ALARM	OUT-SERVICE
M.O.L. 19.5'	Start	Stop				Well 29 Res. Valve	MOVING	LOCAL	ALARM	OUT-SERVICE
Well 16	.1	FT	0			Well 29 Waste Valve	CLOSED	LOCAL	NORMAL	OUT-SERVICE
Well 29	15	FT	17			Well 33 Res. Valve	OPEN	LOCAL	NORMAL	OUT-SERVICE
Well 33	14.5	FT	16.8			Well 33 Waste Valve	CLOSED	LOCAL	NORMAL	OUT-SERVICE

West

RTU-6 - West Reservoir and Pump Station					7 : 53 : 59 Jan/11/2023 8:45:09 AM	
RUN STAT. SW. POS. FAIL AVAILABLE					STATION & VFD STATUS/CONTROL	
Booster 1 (200 HP) VFD	RUN	AUTO	NORMAL	IN-SERVICE	Backup Control STAGING	Station Start Setpoint 80 PSI
Booster 2 (200 HP) VFD	OFF	AUTO	NORMAL	IN-SERVICE		Station Maintain Setpoint 83 PSI
Booster 3 (200 HP)	OFF	AUTO	NORMAL	IN-SERVICE		Auto VFD Lead Select 88
Booster 4 (150 HP)	OFF	AUTO	NORMAL	IN-SERVICE		Select PID Control 0
Booster 5 (100 HP)	OFF	AUTO	NORMAL	IN-SERVICE		Lead VFD Speed 94.98 %
WELLS STAGE SELECTION					CHLORINATION	
Well 20 (150 HP)	RUN	AUTO	NORMAL	IN-SERVICE	1	Residual  .88 PPM
Well 21 (150 HP)	OFF	AUTO	NORMAL	IN-SERVICE	2	NaClO Level  775.6 GAL
Well 30 (200 HP)	OFF	AUTO	NORMAL	IN-SERVICE	0	
ANALOG VALUES		STATUS / CONTROL		SET POINTS		
Bypass Flow	0 CFS	Automatic Control	AUTO	Bypass Valve Enable	25	FT (AND) 86 PSI
Res. Level	23.1 FT	Bypass Valve	CLOSED	Bypass Valve Disable	26	FT (OR) 81 PSI
Disch. Flow	5.8 CFS	Mid-Peak TOU	INACTIVE	Bypass Ctrl Time Start	2300	Stop 600
System Press	84.1 PSI	On-Peak TOU	INACTIVE	Bypass PID Pressure Set Point		83 PSI
CL2 Day Tank	775.6 GAL	BPV TOU Status	INACTIVE	TOU SET POINTS		
Backup Control - Boosters 3, 4, & 5		M.O.L. 27.5'		Mid-Peak TOU Begin (MT)	999	END 999
				On -Peak TOU Begin (MT)	999	END 999
				Wells TOU Override	3	FT
				Low Pressure Override SP	0	PSI
				Low Level Shutdown	3	FT
				Low Level Reset	7	FT
START STOP		START STOP				
Pump Stage 1	80.0 PSI 86.0	Well Stage 1	23 FT 26.75			
Pump Stage 2	79.0 PSI 84.0	Well Stage 2	22 FT 26.5			
Pump Stage 3	77.0 PSI 82.0	Well Stage 3	21 FT 26.25			

South

RTU-7 - South Reservoir and Pump Station			7 : 53 : 59 Jan/11/2023 8:45:09 AM																																																	
<table><thead><tr><th></th><th>RUN STAT.</th><th>SWITCH POS.</th><th>FAIL</th></tr></thead><tbody><tr><td>Booster 1 (125 HP)</td><td>OFF</td><td>AUTO</td><td>NORMAL</td></tr><tr><td>Booster 2 (125 HP)</td><td>OFF</td><td>AUTO</td><td>NORMAL</td></tr></tbody></table>				RUN STAT.	SWITCH POS.	FAIL	Booster 1 (125 HP)	OFF	AUTO	NORMAL	Booster 2 (125 HP)	OFF	AUTO	NORMAL	<table><thead><tr><th></th><th>START</th><th>STOP</th></tr></thead><tbody><tr><td>Lead VFD</td><td>88.9 PSI</td><td>100 PSI</td></tr><tr><td>Lag VFD</td><td>87 PSI</td><td>96 PSI</td></tr><tr><td>System Maintain Setpoint</td><td>94 PSI</td><td></td></tr><tr><td>M.O.L. 17.5'</td><td></td><td></td></tr><tr><td>Well 34</td><td>13 FT</td><td>15 FT</td></tr><tr><td>VFD 1 Lead</td><td></td><td>VFD 2 Lead </td></tr></tbody></table>			START	STOP	Lead VFD	88.9 PSI	100 PSI	Lag VFD	87 PSI	96 PSI	System Maintain Setpoint	94 PSI		M.O.L. 17.5'			Well 34	13 FT	15 FT	VFD 1 Lead		VFD 2 Lead															
	RUN STAT.	SWITCH POS.	FAIL																																																	
Booster 1 (125 HP)	OFF	AUTO	NORMAL																																																	
Booster 2 (125 HP)	OFF	AUTO	NORMAL																																																	
	START	STOP																																																		
Lead VFD	88.9 PSI	100 PSI																																																		
Lag VFD	87 PSI	96 PSI																																																		
System Maintain Setpoint	94 PSI																																																			
M.O.L. 17.5'																																																				
Well 34	13 FT	15 FT																																																		
VFD 1 Lead		VFD 2 Lead																																																		
<table><thead><tr><th>RUN STAT.</th><th>SWITCH POS.</th><th>FAIL</th></tr></thead><tbody><tr><td>Well 34 (125 HP)</td><td>AUTO</td><td>NORMAL</td></tr></tbody></table>			RUN STAT.	SWITCH POS.	FAIL	Well 34 (125 HP)	AUTO	NORMAL																																												
RUN STAT.	SWITCH POS.	FAIL																																																		
Well 34 (125 HP)	AUTO	NORMAL																																																		
<table><thead><tr><th colspan="3">ANALOG VALUES</th></tr></thead><tbody><tr><td>Bypass Flow</td><td>0</td><td>CFS</td></tr><tr><td>Res. Level</td><td>15</td><td>Ft</td></tr><tr><td>Disch. Flow</td><td>0</td><td>CFS</td></tr><tr><td>System Press</td><td>93.5</td><td>PSI</td></tr><tr><td>Well 34 Flow</td><td>0</td><td>CFS</td></tr><tr><td>Well 34 CL2 Tank Level</td><td>400.8</td><td>Gal</td></tr><tr><td>Fwd Totalizer</td><td>64,428,748</td><td>CF</td></tr><tr><td>Rev Totalizer</td><td>-57,581</td><td>CF</td></tr></tbody></table>			ANALOG VALUES			Bypass Flow	0	CFS	Res. Level	15	Ft	Disch. Flow	0	CFS	System Press	93.5	PSI	Well 34 Flow	0	CFS	Well 34 CL2 Tank Level	400.8	Gal	Fwd Totalizer	64,428,748	CF	Rev Totalizer	-57,581	CF	<table><thead><tr><th colspan="3">STATUS / CONTROL</th></tr></thead><tbody><tr><td>Automatic Control</td><td>AUTO</td><td></td></tr><tr><td>Bypass Valve</td><td>CLOSED</td><td></td></tr><tr><td>Bypass Valve</td><td>INACTIVE</td><td></td></tr><tr><td>TOU Status</td><td></td><td></td></tr><tr><td>Mid-Peak Tou Status</td><td>INACTIVE</td><td></td></tr><tr><td>On Peak TOU Status</td><td>INACTIVE</td><td></td></tr></tbody></table>		STATUS / CONTROL			Automatic Control	AUTO		Bypass Valve	CLOSED		Bypass Valve	INACTIVE		TOU Status			Mid-Peak Tou Status	INACTIVE		On Peak TOU Status	INACTIVE	
ANALOG VALUES																																																				
Bypass Flow	0	CFS																																																		
Res. Level	15	Ft																																																		
Disch. Flow	0	CFS																																																		
System Press	93.5	PSI																																																		
Well 34 Flow	0	CFS																																																		
Well 34 CL2 Tank Level	400.8	Gal																																																		
Fwd Totalizer	64,428,748	CF																																																		
Rev Totalizer	-57,581	CF																																																		
STATUS / CONTROL																																																				
Automatic Control	AUTO																																																			
Bypass Valve	CLOSED																																																			
Bypass Valve	INACTIVE																																																			
TOU Status																																																				
Mid-Peak Tou Status	INACTIVE																																																			
On Peak TOU Status	INACTIVE																																																			
			<table><thead><tr><th colspan="5">BYPASS VALVE SET POINTS</th></tr></thead><tbody><tr><td>Open</td><td><</td><td>16</td><td>AND ></td><td>100</td></tr><tr><td>Close</td><td>></td><td>17</td><td>OR <</td><td>89.9</td></tr><tr><td>PID Pressure SP</td><td></td><td>92.9</td><td>Override</td><td>100</td></tr><tr><td>Start Time</td><td></td><td>999</td><td>Stop Time</td><td>999</td></tr></tbody></table>		BYPASS VALVE SET POINTS					Open	<	16	AND >	100	Close	>	17	OR <	89.9	PID Pressure SP		92.9	Override	100	Start Time		999	Stop Time	999																							
BYPASS VALVE SET POINTS																																																				
Open	<	16	AND >	100																																																
Close	>	17	OR <	89.9																																																
PID Pressure SP		92.9	Override	100																																																
Start Time		999	Stop Time	999																																																
			<table><thead><tr><th colspan="5">T.O.U. SET POINTS</th></tr></thead><tbody><tr><td>Mid-Peak TOU Begin</td><td>999</td><td>End</td><td>999</td><td>MT</td></tr><tr><td>On Peak TOU Begin</td><td>999</td><td>End</td><td>999</td><td>MT</td></tr><tr><td colspan="5">Station</td></tr><tr><td>Low Level Shutdown</td><td>0</td><td colspan="3"></td></tr><tr><td>Low Level Reset</td><td>2.5</td><td colspan="3"></td></tr></tbody></table>		T.O.U. SET POINTS					Mid-Peak TOU Begin	999	End	999	MT	On Peak TOU Begin	999	End	999	MT	Station					Low Level Shutdown	0				Low Level Reset	2.5																					
T.O.U. SET POINTS																																																				
Mid-Peak TOU Begin	999	End	999	MT																																																
On Peak TOU Begin	999	End	999	MT																																																
Station																																																				
Low Level Shutdown	0																																																			
Low Level Reset	2.5																																																			

Appendix B

The Village Project Proposed Land Use Plan

3.2 Land Use Plan

The land use plan is the basis for establishing the range of uses, maximum buildout, and development standards for the Village. The Village is a mixed-use community that allows for vertical and horizontal mixed use across the site. As shown on Figure 3-1, *Proposed Land Use Plan*, a variety of residential, commercial, and community uses are planned throughout the Village. A central commercial area in a park setting allows for restaurants and retail uses to activate the area during both day and night. A continuation of those commercial uses is encouraged at the ground floor of adjacent residential buildings. Parking would be readily available in at-grade and underground structures. Figure 3-2a, *Conceptual Site Plan*, depicts how the plan could be implemented. As noted in the figure, various commercial uses, including

restaurants, retail shops, and a grocery store/market, may enhance the plaza and create a sense of place at the heart of the Village. Stand-alone residential and mixed-use buildings provide a variety of housing opportunities for residents who seek a unique community in the city’s South Bristol Focus Area.

3.2.1 Maximum Buildout

The maximum buildout for the Village is provided in Table 3-1, *Land Use Statistical Summary*. This Specific Plan allows up to 1,583 dwelling units, 80,000 square feet of commercial space, 300,000 square feet of office, and over 3.6 acres of open space. Chapter 4, *Development Regulations*, provides more detail regarding permitted uses and development standards for each use.


Table 3-1: Land Use Statistical Summary

Uses ¹	Development	Site Size
Residential	1,583 units (maximum)	17 Acres
Commercial	80,000 sq ft (maximum)	
Office	300,000 sq ft (maximum)	
Open Space ²	158,300 sq ft (approximately 3.6 acres, minimum)	


Notes:
1. Uses are permitted as vertical and/or horizontal mixed use.
2. Open Space areas consist of passive and active areas as defined by the City of Santa Ana 2022 Housing Element.

Figure 3-1: Proposed Land Use Plan

Ground Level



Rooftop




Source: Gensler, PlaceWorks

Appendix C

Extended-Period Simulation Results


The Village Project Demand

Low Pressure Zone



The Village On-Site Pressure

Low Pressure Zone



LEGEND

- Existing
- Existing + The Village


Figure A.1 Onsite Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




PRV-1 Flow

High Pressure Zone




PRV-1 Upstream Pressure

Low Pressure Zone




PRV-2 Flow

High Pressure Zone



PRV-2 Upstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.2 PRV Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




PRV-3 Flow

Low Pressure Zone




PRV-3 Upstream Pressure

Low Pressure Zone




PRV-4 Flow

Low Pressure Zone



PRV-4 Upstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout

Figure A.3


PRV Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




SA-1 Flow

Low Pressure Zone




SA-1 Downstream Pressure

Low Pressure Zone




SA-2 Flow

Low Pressure Zone



SA-2 Downstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout

Figure A.4


Turnout Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




SA-3 Flow

Low Pressure Zone




SA-3 Downstream Pressure

Low Pressure Zone




SA-4 Flow

Low Pressure Zone



SA-4 Downstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.5 Turnout Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




SA-5 Flow

Low Pressure Zone




SA-5 Downstream Pressure

Low Pressure Zone




SA-6 Flow

High Pressure Zone



SA-6 Downstream Pressure

High Pressure Zone



LEGEND

- Existing
- Buildout

Figure A.6


Turnout Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




SA-7 Flow

Low Pressure Zone



SA-7 Downstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.7 Turnout Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Garthe Tank Level

Low Pressure Zone




Garthe Station Downstream Pressure

Low Pressure Zone




Garthe Pump Head

Low Pressure Zone



Garthe Pump Flow

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.8 Station Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Walnut Tank Level

Low Pressure Zone




Walnut Station Downstream Pressure

Low Pressure Zone




Walnut Pump Head

Low Pressure Zone



Walnut Pump Flow

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.9 Station Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




East Tank Level

Low Pressure Zone




East Station Downstream Pressure

Low Pressure Zone




East Pump Head

Low Pressure Zone



East Pump Flow

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.10 Station Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




West Tank Level

Low Pressure Zone




West Station Downstream Pressure

Low Pressure Zone




West Pump Head

Low Pressure Zone



West Pump Flow

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.11 Station Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




South Tank Level

Low Pressure Zone




South Station Downstream Pressure

Low Pressure Zone




South Pump Head

Low Pressure Zone



South Pump Flow

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.12 Station Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Cambridge Tank Level

High Pressure Zone




Cambridge Station Downstream Pressure

High Pressure Zone




Cambridge Pump Head

High Pressure Zone



Cambridge Pump Flow

High Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.13 Station Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Crooke Tank Level

High Pressure Zone




Crooke Station Downstream Pressure

High Pressure Zone




Crooke Pump Head

High Pressure Zone



Crooke Pump Flow

High Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.14 Station Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana



Elevated Tank Level

Low Pressure Zone



LEGEND

- Existing
- Buildout

April 18, 2024


Figure A.15
Station Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Well 18 Flow

Low Pressure Zone




Well 18 Downstream Pressure

Low Pressure Zone




Well 20 Flow

Low Pressure Zone



Well 20 Downstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout

Figure A.16


Well Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Well 21 Flow

Low Pressure Zone




Well 21 Downstream Pressure

Low Pressure Zone




Well 24 Flow

Low Pressure Zone



Well 24 Downstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.17 Well Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Well 26 Flow

Low Pressure Zone




Well 26 Downstream Pressure

Low Pressure Zone




Well 29 Flow

Low Pressure Zone



Well 29 Downstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.18 Well Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Well 30 Flow

Low Pressure Zone




Well 30 Downstream Pressure

Low Pressure Zone




Well 31 Flow

Low Pressure Zone



Well 31 Downstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.19 Well Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Well 33 Flow

Low Pressure Zone




Well 33 Downstream Pressure

Low Pressure Zone




Well 34 Flow

Low Pressure Zone



Well 34 Downstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.20 Well Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Well 35 Flow

Low Pressure Zone




Well 35 Downstream Pressure

Low Pressure Zone




Well 36 Flow

Low Pressure Zone



Well 36 Downstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.21 Well Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Well 37 Flow

Low Pressure Zone




Well 37 Downstream Pressure

Low Pressure Zone




Well 39 Flow

Low Pressure Zone



Well 39 Downstream Pressure

Low Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.22 Well Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Well 41 Flow

Low Pressure Zone




Well 41 Downstream Pressure

Low Pressure Zone




Well 27 Flow

High Pressure Zone



Well 27 Downstream Pressure

High Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.23 Well Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Well 28 Flow

High Pressure Zone




Well 28 Downstream Pressure

High Pressure Zone




Well 38 Flow

High Pressure Zone



Well 38 Downstream Pressure

High Pressure Zone



LEGEND

- Existing
- Buildout


Figure A.24 Well Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana




Well 40 Flow

High Pressure Zone



Well 40 Downstream Pressure

High Pressure Zone



LEGEND

- Existing
- Buildout

Figure A.25 Well Comparison

Hydraulic Model Evaluation for
The Village Project
City of Santa Ana

