

Notice of Determination

TO: Office of Land Use and Climate Innovation
State Clearinghouse
P.O. Box 3044, Room 113
Sacramento, CA 95812-3044

FROM: Central Valley Flood Protection Board (Board)
3310 El Camino Avenue, Suite 170
Sacramento, CA 95821
Angela Nguyen-Tan, (916) 837-3717
Angela.Nguyen-Tan@cvflood.ca.gov

SUBJECT: Filing of Notice of Determination pursuant to Public Resources Code Section 21108.

State Clearinghouse Number (SCH No.): 2020070575

Project Title: Permit No. 19662-1 – American River Watershed Common Features, Water Resources Development Act of 2016 Project, Sacramento Weir Widening: Installation Telecommunication Utilities

Project Applicant: Pacific Gas and Electric,(PG&E) Laura Navarro, Permit Coordinator; 850 Stillwater Road, West Sacramento, CA 95605; (530) 215-9648; laura.navarro@pge.com;

Lead Agency: Central Valley Flood Protection Board, 3310 El Camino Ave, Ste 170, Sacramento, CA 95821

Project Location: This project is located on Old River Road starting from Levee Rd and extending approximately 3,100 feet north on Old River Road from Levee mile 3.13 to 3.76, West Sacramento, Yolo County (38.611747, - 121.562026).

Project Description: Approval of Permit No. 19662-1, under California Code of Regulations, Title 23, Article 3, Section 6, for work within an adopted plan of flood control: To authorize the installation of nine (9) new PG&E poles on the landside of Old River Road. Four (4) of the poles will be 50-foot Class 1 poles set at a depth of 8 feet below grade, and five (5) will be 50-foot Class 2 poles set at a depth of 8 feet below grade. The project includes the installation of 1,378 linear feet of overhead electrical cable; attachment of 1,600 linear feet of electrical cable on downstream side, below the deck of the new Sacramento Weir bridge; installation of 230 linear feet of underground cables at a depth of 2 feet below grade (two 6-inch electrical conduits spaced 9 inches apart and one 4-inch communication conduit located 12 inches from the nearest electrical conduit); and removal of the existing 14 temporary poles (Board Permit No. 19662, issued on 7/22/2022) located on the east side of Old River Road..

This is to advise that the Board, as the **Responsible Agency**, approved the above-described project on 4/14/2026 and made the following determinations regarding the above-described project:

1. The project [will / will not] have a significant effect on the environment (This determination is limited to effects within the Board’s permitting jurisdiction as a responsible agency).
2. [An Environmental Impact Report (EIR) / A Mitigated Negative Declaration] was prepared by the lead agency for the original project.
3. Additional mitigation measures [were / were not] made a condition of the Board’s approval of the project.
4. A Mitigation Monitoring and Reporting Plan [was / was not] adopted by the Board for this project
5. A Statement of Overriding Considerations [was / was not] adopted by the Board for this project.
6. Findings [were / were not] made by the Board pursuant to the provisions of CEQA.

Responsible Agency Statement: The EIR, prepared by the lead agency for the project, is available to the general public at the lead agency’s office listed above. The Board’s administrative record related to the Board permit is available for public review at the Board’s office.

	<i>Chris Lief</i>	4/15/2026
Signature	Chris Lief, Executive Officer	Date

Authority cited: Sections 21083, Public Resources Code.
Reference: Sections 21100-21174, Public Resources Code.