Notice of Exemption

To:
Office of Planning and Research
P.O. Box 3044, Room 113
Sacramento, CA 95812-3044

From:
State Water Resources Control Board
Division of Drinking Water
1350 Front Street, Room 2050
San Diego, CA 92101
Omar Khan
619-525-4159

Lead Agency: Western Municipal Water District

Lead Agency Contact: Lyndy Lewis

Lead Agency Phone Number: 951-571-7277

State Clearinghouse Number:

Project Title: Western Municipal Water District (Murrieta Division) - North Well 2 (Project)

Project Address: 24308 Kentucky Derby Way, Murrieta, CA 92562

Project Description:

The project involves the replacement of North Well with North Well 2, located within the same well site property. North Well was destroyed in November 2019, due to poor well casing conditions and decreased water yield The project involves installation of a 750 gallon per minute potable well (North Well 2), chloramination treatment, and other appurtenances.

Public Agency Approving the Project: State Water Resources Control Board (State Water Board)

This is to advise that the State Water Board has issued approval for the described project on 01/21/2021. A record of approval for the Project is available to the general public at the State Water Board, Division of Drinking Water District Office noted above.

Exempt Status:

Categorical Exemption(s)

Class 2 Replacement or Reconstruction (California Code of Regulations, Title 14, Division 6, Chapter 3, Article 19, Section 15302

Reason why project is exempt:

North Well 2 is a replacement of North Well, with substantially the same purpose and capacity.

Signature: Digitally signed by Sean F. McCarthy Date: 2021.01.26 08:05:04 -08'00'

Date: 1/26/21

Name: Sean F. McCarthy

Title: District Engineer

Authority cited: Sections 21083 and 21110, Public Resources Code. Reference: Sections 21108, 21152, and 21152.1, Public Resources Code.

Date Received for filing at Office of Planning and Research:

Revised 12/18/20