NOTICE OF EXEMPTION

TO:
Governor's Office of Land Use and Climate Innovation
State Clearinghouse
1400 Tenth Street, Room 113
Sacramento, CA 95812

FROM:
State Water Resources Control Board
Division of Drinking Water (DDW)
3021 Reynolds Ranch Pkwy, STE 260
Lodi, CA 95240
Bhupinder Sahota
Phone: (209) 948-7696

Project Applicant: San Joaquin County – Raymus Village

Project Title: Raymus Village 1,2,3 – Trichloropropane Mitigation Project – Water Supply Permit Amendment

Project Location: 14560 Pueblo Dr, Manteca, CA 95336 (Southeast corner of Raymus Village Park), APN: 197-110-47

Project County: San Joaquin

Project Description: The Applicant proposes the operation of their new granular activated carbon (GAC) treatment system which was installed adjacent to their existing Well 2. The new treatment system consists of four ten-foot diameter GAC vessels for the removal of 1,2,3 – Trichloropropane and a 25,000-gallon backwash tank.

Public Agency Approving the Project: State Water Resources Control Board (State Water Board)

This is to advise that the State Water Board has issued a permit amendment for the above-described Project on 11/5/2025. A record of approval for the Project is available to the general public at the State Water Board, Division of Drinking Water district office listed above.

CATEGORICAL EXEMPTION STATUS:

- Class 1: Existing Facilities**,** California Code of Regulations, title 14, division 6, chapter 3, article 19, section 15301

Reason Why the Project Is Exempt: The Project is exempt because it is the operation of a treatment system at an existing public water system facility with no change in use. None of the exceptions listed in section 15300.2 of the CEQA Guidelines would apply to the proposed Project.

Wendy Pierce Digitally signed by Wendy Pierce
Date: 2025.11.10 13:07:19 -08'00'
Water Boards

Senior Environmental Scientist

Authority cited: Sections 21083 and 21110, Public Resources Code. Reference: Sections 21108, 21152, and 21152.1, Public Resources Code.