



CLIMATE ACTION PLAN CONSISTENCY REVIEW CHECKLIST

INTRODUCTION

The City of San Marcos (City) adopted an updated Climate Action Plan (CAP) in December, 2020. The CAP outlines strategies and measures that the City will undertake to achieve its proportional share of State greenhouse gas (GHG) emissions reduction targets. The purpose of the CAP Consistency Checklist (Checklist), in conjunction with the CAP, is to provide a streamlined review process for all proposed development projects that are subject to discretionary review and/or trigger environmental review pursuant to the California Environmental Quality Act (CEQA).

Analysis of GHG emissions and potential climate change impacts from new development is required under CEQA. The City's CAP is a qualified greenhouse gas (GHG) emissions reduction plan in accordance with State CEQA Guidelines Section 15183.5. Pursuant to CEQA Guidelines Sections 15064(h)(3), 15130(d), and 15183(b), a project's incremental contribution to a cumulative GHG emissions effect may be determined not to be cumulatively considerable if it complies with the requirements of a CAP.

The purpose of this Checklist is to implement GHG reduction measures from the CAP that apply to new discretionary development projects. New development would demonstrate consistency with relevant CAP strategies and would not conflict with the City's ability to achieve the identified GHG reduction targets through implementation of applicable measures. Projects that are consistent with the CAP, as determined through the use of this Checklist, may rely on the CAP for the cumulative impact analysis of GHG emissions. Projects that are not consistent with the CAP must prepare a comprehensive project-specific analysis of GHG emissions, including quantification of existing and projected GHG emissions and incorporation of the measures in this Checklist to the extent feasible. Cumulative GHG impacts would be significant for any project that is not consistent with the CAP.

This Checklist may be updated periodically to incorporate new GHG reduction techniques or to comply with later amendments to the CAP or local, State, or federal law. Comprehensive updates to this Checklist will be coordinated with each CAP update. Administrative updates to the Checklist may occur regularly, as necessary for the purpose of keeping the Checklist up-to-date and implementable. Updates to the CAP Checklist associated with an update to the City's CAP would also require City Council approval and shall comply with CEQA.



APPLICABILITY AND PROCEDURES

This Checklist is required only for discretionary projects¹ that are subject to and not exempt from CEQA. Projects that are exempt from CEQA are deemed to be consistent with the City's CAP, and no further review is necessary, with the exception of a Class 32 "In-Fill Development Projects" categorical exemption (State CEQA Guidelines Section 15332), for which projects are required to demonstrate consistency with the CAP through this Checklist.

General procedures for Checklist compliance and review are described below. Specific guidance is also provided under each of the questions under Steps 1 and 2 of the Checklist.

- The City's Development Services - Planning Division reviews development applications and makes determinations regarding environmental review requirements under CEQA.
- The specific applicable requirements outlined in the Checklist shall be required as conditions of project approval.
- The project must provide written documentation and supporting evidence that demonstrate how the proposed project would implement each applicable Checklist requirement described herein to the satisfaction of the Planning Division.
- If a question in the Checklist is deemed not applicable (N/A) to a project, written documentation and evidence supporting that conclusion shall be provided to the satisfaction of the Planning Division. Each Checklist question provides the scenario(s) where checking N/A may be acceptable. If a measure is deemed not applicable for reasons other than those outlined in each question, supporting evidence will need to be provided and would be subject to Planning Division approval. A project may be determined to be inconsistent with the CAP if the N/A response is deemed to be not supported by credible evidence.
- Development projects requiring discretionary review that cannot demonstrate consistency with the CAP using this Checklist shall prepare a separate, project-level GHG analysis as part of the CEQA document prepared for the project.

¹ In this context, a project is any action that meets the definition of a "Project" in Section 15378 of the State CEQA Guidelines.



Application Information

Contact Information

Project No. and Name: Armorlite Lofts

Property Address and APN: 219-162-57

Applicant Name and Co.: Avenue Development Partners, LLC

Contact Phone: 619-981-0579 Contact Email: dan@avenuesecond.com

Was a consultant retained to complete this checklist? Yes No

If Yes, complete the following:

Consultant Name: Jason Greminger Contact Phone: 760-471-2365

Company Name: CCI Contact Email: _____

Project Information

1. What is the size of the project site (acres)? 2.44-acres

2. Identify all applicable proposed land uses:

- Residential (indicate # of single-family dwelling units): _____
- Residential (indicate # of multi-family dwelling units): _____
- Commercial (indicate total square footage): _____
- Industrial (indicate total square footage): _____
- Other (describe): Mixed-use 165 dwelling units & approx. 5,600 SF commercial/retail/flex space

3. Provide a description of the project proposed. This description should match the basic project description used for the CEQA document. The description may be attached to the Checklist if there are space constraints.

The project includes 165 multi-family dwelling units and approximately 5,600 SF of commercial/retail/flex space. 15% of the dwelling units will be affordable dwelling units in the very-low income 30% to 50% AMI.



STEP 1: LAND USE CONSISTENCY

The first step in this section evaluates a project's GHG emissions consistent with the City's *Guidance to Demonstrating Consistency with the City of San Marcos Climate Action Plan: For Discretionary Projects Subject to CEQA* (Guidance Document). New discretionary development projects subject to CEQA review that emit fewer than 500 metric tons of carbon dioxide equivalent (MTCO₂e) annually would not contribute considerably to cumulative climate change impacts as stated in the City's Guidance Document, and therefore, would be considered consistent with the CAP and associated emissions projections.

For projects that are subject to CAP consistency review, the next step in determining consistency is to assess the project's consistency with the growth projections used in the development of the CAP. This section allows the city to determine a project's consistency with the land use assumptions used in the CAP.



Step 1: Land Use Consistency

Checklist Item <small>(Check the appropriate box and provide an explanation and supporting documentation for your answer)</small>	Yes	No
<p>1. The size and type of projects listed below would emit fewer than 500 MTCO₂e per year. Based on this threshold, does the proposed project exceed these characteristics?</p> <ul style="list-style-type: none"> ▪ <u>Single Family Housing</u>: 36 dwelling units ▪ <u>Multi-Family Housing</u>: 55 dwelling units ▪ <u>Office</u>: 43,000 square feet ▪ <u>Commercial Space</u>: 20,000 square feet ▪ <u>Regional Shopping Center</u>: 18,000 square feet ▪ <u>Hotel</u>: 37 rooms ▪ <u>Restaurant (Sit-Down)</u>: 6,500 square feet ▪ <u>Restaurant (Drive-Thru, High Turnover)</u>: 2,400 square feet ▪ <u>General Light Industrial</u>: 58,000 square feet ▪ <u>University</u>: 263 students ▪ <u>Mixed-Use</u>: See <i>Guidance to Demonstrating Consistency</i> memorandum for methods to estimate mixed-use development thresholds ▪ <u>Other</u>: For project types not listed in this section the need for GHG analysis and mitigation will be made on a project-specific basis, considering the 500 MTCO₂e per year screening threshold. <p>If “Yes”, proceed to Question 2 of Step 1. If “No”, in accordance with the City’s CAP screening criteria, the project’s GHG impact is less than significant and is not subject to the measures of the CAP.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
<p>2. Is the proposed project consistent with the City’s existing General Plan land use designation?</p> <p>If “Yes”, proceed to Step 2. If “No”, proceed to Question 3 of Step 1</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
<p>3. For projects not consistent with the existing General Plan land use designation, does the project include a General Plan Amendment that would generate GHG emissions equal to or less than estimated emissions generated under the existing designation?</p> <p>If “Yes”, proceed to Step 2 and provide estimated project emissions under both existing and proposed designation(s) for comparison. If “No”, the project’s GHG impact is potentially significant, and a GHG analysis must be prepared in accordance with the City’s Guidance Document and applicable CEQA guidelines. The project must incorporate each of the measures identified in Step 2 to mitigate cumulative GHG emissions impacts, along with other mitigation measures as necessary based on a project specific GHG analysis.. Proceed and complete a project specific GHG analysis, and Step 2 of the Checklist.</p>	<input type="checkbox"/>	<input checked="" type="checkbox"/>



STEP 2: CAP MEASURES CONSISTENCY

The second step of CAP consistency review is to evaluate a project’s consistency with the applicable strategies and measures of the CAP. Each Checklist item is associated with a specific GHG reduction measure in the City’s CAP. “N/A” should only be checked based on the direction provided in each Checklist Item question. All projects for which the measure is applicable must demonstrate that they would implement measures consistent with the Checklist Item, or fully substantiate how the item would be infeasible for project implementation. “N/A” responses are subject to Planning Division review and approval. If “No” is provided as a response to a question, the project would be determined to be inconsistent with the CAP and result in a significant GHG impact.



Step 2: CAP Measures Consistency

Checklist Item (Check the appropriate box and provide an explanation for your answer. Please use additional sheets if necessary)	Yes	No	N/A
Project Design			
<p>1. Electric Vehicle Charging Stations (Measure T-2)</p> <p><u>Multi-Family Residential and Non-Residential:</u> Will the project install electric vehicle charging stations (Level 2 or better) in at least five percent of the total parking spaces provided on-site?</p> <p>Check “N/A” if the project is a single-family residential project or would not provide any parking.</p> <p>Please substantiate how the project satisfies question 1. Indicate the total number of spaces and the number of EV chargers (should be 5% of more of total spaces): <u>The project will install at least 8 level 2 EV charging stations and/or comply with Calgreen whichever is more stringent.</u></p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<p>2. Bicycle Infrastructure (Measure T-8)</p> <p><u>Residential and Non-Residential Projects:</u> If the following conditions are met, would the project pay its fair-share contribution to bicycle infrastructure improvements?</p> <ul style="list-style-type: none"> <input type="checkbox"/> Intersection or roadway segment improvements are proposed as part of the project and, <input type="checkbox"/> The City’s General Plan Mobility Element identifies bicycle infrastructure improvements at any intersection(s) or roadway segment(s) that would be improved as part of the project. <p>Check “N/A” if the conditions above would not be met.</p> <p>Please substantiate how the project satisfies question 2: <u>Surrounding roadways are constructed to ultimate configurations including bicycle facilities and no other improvements are necessary.</u></p>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>



Step 2: CAP Measures Consistency

Checklist Item <small>(Check the appropriate box and provide an explanation for your answer. Please use additional sheets if necessary)</small>	Yes	No	N/A
<p>3. Transportation Demand Management (Measure T-9)</p> <p><u>Multi-Family Residential and Non-Residential:</u> Will the project develop and implement a TDM plan that includes, at a minimum, all of the TDM strategies listed below?</p> <ul style="list-style-type: none"> <input checked="" type="checkbox"/> Provide discounted monthly transit pass or provide at least 25 percent transit fare subsidy to residents/employees. <input checked="" type="checkbox"/> Provide designated car-share, carpool, vanpool, and/or park-and-ride parking spaces.² <input checked="" type="checkbox"/> Provide pedestrian connections between all internal uses and to all existing or planned external streets around the project site(s). <input checked="" type="checkbox"/> Provide secure bicycle parking spaces or bicycle racks, showers, and clothes lockers. <input checked="" type="checkbox"/> Encourage telecommuting for employees (allow one telecommute day per week or compressed work weeks) or provide a telecommute work center with common office space and equipment available to residents. <p style="text-align: center;">-or-</p> <p>Would the project implement and monitor for four (4) years a TDM program that demonstrates an alternative transportation (i.e. carpool, public transit, bicycle, walk, telecommute) mode share of at least 29 percent ³ for all residents?</p> <p>Check “N/A” if the project is a single-family residential project or is not subject to the City’s TDM Ordinance.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Please state which measure option the project for which the project would comply and substantiate how the project satisfies question 3:

The TDM will require the building manager to make transit passes available to residents and businesses of the bldg. Carpool/vanpool/park & ride parking will be provided. A pedestrian connection is provided from the building to Armorlite Drive. Bicycle racks will be provided for visitors. Residents have shower facilities within apartments. Work-space will be provided to residents in the community room for residents who wish to work remote

² The designated number of car-share, carpool, vanpool, and/or park-and-ride parking spaces provided at a rate equal to or greater than CALGreen minimum requirements.
³ Measure T-10 requires projects to increase alternative mode share by seven percent. The baseline mode share for alternative transportation (i.e. carpool, public transit, bicycle, walk, and telecommute) is 22 percent based on 2010 Census Data.



Step 2: CAP Measures Consistency

Checklist Item (Check the appropriate box and provide an explanation for your answer. Please use additional sheets if necessary)	Yes	No	N/A
<p>4. Reduce Parking Near Transit (Measure T-12)</p> <p><u>Multi-Family Residential:</u> If located within a half-mile of a major transit stop⁴, would the project provide at least 27 percent fewer parking spaces than required for the same use based on the City's municipal code parking requirements?</p> <p>Check "N/A" if the project is a single-family residential or non-residential project.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<p>Please substantiate how the project satisfies question 4. Indicate total parking spaces that are required per the City's Zoning Ordinance and the total number of spaces as proposed: a 27% reduction in parking has been included in the parking ratio.</p> <hr/> <hr/> <hr/> <hr/>			
<p>5. Water Heaters (Measure E-1)</p> <p>Residential: Will the project install one of, or a combination of, the following water heater types in place of natural gas water heaters?</p> <ul style="list-style-type: none"> <input checked="" type="checkbox"/> Electric heat pump water heater <input type="checkbox"/> Instantaneous electric water heater <input type="checkbox"/> Electric tank <input type="checkbox"/> Solar water heater with heat pump water heater backup <input type="checkbox"/> Solar water heater with electric tank backup <p>Check "N/A" if the project is a non-residential project.</p>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

⁴ Major transit stop is defined as a bus or light-rail station with fixed service and 10-minute minimum headways during peak hours. Project applicants should confirm with City staff if the project site would fall within this proximity to a major transit stop.



Step 2: CAP Measures Consistency

Checklist Item

(Check the appropriate box and provide an explanation for your answer. Please use additional sheets if necessary)

Yes

No

N/A

Please substantiate how the project satisfies question 5. A note should be added to the Floor plans and site plan to show that Building Permit Plan will include this requirement:

Electric heat pump water heaters will be used for residential heating within the building.

6. Photovoltaic Installation (Measure E-2)

Non-Residential: Will the project install photovoltaic systems with a minimum capacity of two watts per square foot of gross floor area?

Check "N/A" if the project is a residential project or if installation of on-site photovoltaic would be infeasible.

Please substantiate how the project satisfies question 6. The Photovoltaic systems should be included in the Roof Plan/Site Plan (as applicable) and a note should be added to the Plans set to show that Building Permit Plan will include this requirement::

A Photovoltaic rooftop system will be installed to help offset energy use.

7. Landscaping Water Use (Measure W-1)

Residential and Non-Residential: Will the project comply with the City's Water Efficient Landscape Ordinance?⁵

Check "N/A" if the project is not proposing any landscaping or is not subject to the City's Water Efficient Landscape Ordinance.

⁵ City of San Marcos Landscape Manual: <https://www.san-marcos.net/home/showdocument?id=13984>



Step 2: CAP Measures Consistency

Checklist Item

(Check the appropriate box and provide an explanation for your answer. Please use additional sheets if necessary)

Yes

No

N/A

Please substantiate how the project satisfies question 7. Include total landscape area that is subject to WELO:

The project will be WELO compliant.

8. Urban Tree Canopy (Measure C-2)

Single-Family Residential: Will the project plant a minimum of one tree per single-family residential unit?

-or-

Multi-Family Residential and Non-Residential: If the project is providing more than 10 parking spaces, will the project plant at least one tree per five parking spaces provided?

Check "N/A" if planting the required number of trees on-site would be infeasible.

Please substantiate how the project satisfies question 8. Include total number of tree (which should be the same as indicated on Landscape Plans):

The project includes a total of 66 outdoor uncovered parking spaces. Therefore the project is required to provide a total of 13 trees and will provide a total of 49 trees.
