

NOTICE OF EXEMPTION

TO:

Governor's Office of Land Use and Climate
Innovation
State Clearinghouse
1400 Tenth Street, Room 113
Sacramento, CA 95812

FROM:

State Water Resources Control Board
Division of Drinking Water (DDW)
2375 Northside Drive, Suite 100
San Diego CA 92108
Chun Y. Huang
Phone: (619) 525-4159

Project Applicant: City of San Jacinto

Project Title: New Bath Treatment Plant (Project)

Project Location: 254 Camino Los Banos, San Jacinto, CA 92583

Project County: Riverside

Project Description: The project involves construction of a 2500 gpm wellhead treatment system to reduce iron and manganese concentrations in the water produced by Bath Well and Artesia Well. The project is replacing the existing Bath Treatment Plant facility and is located on the same property. The project includes a new backwash tank (38 ft. diameter x 16 ft. height).

Public Agency Approving the Project: State Water Resources Control Board (State Water Board)

This is to advise that the State Water Board has issued interim approval for the above-described Project on March 16, 2026. A record of approval for the Project is available to the general public at the State Water Board, Division of Drinking Water district office listed above.

CATEGORICAL EXEMPTION STATUS:

Class 2: Replacement or Reconstruction Cal. Code of Regs., section 15302

Reason Why the Project Is Exempt: The Project is exempt because for the Project components meet the criteria under Section 15302 for replacement of existing structures and facilities where the new structure is to be located at the same site as the structure replaced and will have substantially the same purpose as the structure replaced. None of the exceptions listed in section 15300.2 of the CEQA Guidelines would apply to the proposed Project.

Signature: _____

Title: Sr. Water Resource Engineer