

Notice of Exemption

Appendix E

To: Office of Planning and Research
P.O. Box 3044, Room 113
Sacramento, CA 95812-3044

County Clerk

County of: Imperial

From: (Public Agency): Imperial Irrigation District

P.O. Box 937

Imperial, CA 92250

(Address)

Project Title: El Centro Generating Station Unit 2-2 Gas Turbine Generator Major Overhaul Project (No. 2.00366)

Project Applicant: Imperial Irrigation District

Project Location - Specific:

485 E. Villa Avenue, El Centro, CA 92243

Project Location - City: El Centro, CA

Project Location - County: Imperial

Description of Nature, Purpose and Beneficiaries of Project:

The ECGS Unit 2-2 gas turbine has been in operation since 1993. Based on its operating hours and working conditions, a major inspection is required to maintain reliable and safe operations. The inspection will include disassembly of the compressor and combustion sections, complete internal inspection, dimensional analysis, and comparison against OEM specifications. The generator rotor will be removed for inspection and electrical testing of both the rotor and stator. All components will be cleaned, evaluated, and repaired to specification or replaced as necessary.

Name of Public Agency Approving Project: IMPERIAL IRRIGATION DISTRICT

Name of Person or Agency Carrying Out Project: IMPERIAL IRRIGATION DISTRICT

Exempt Status: (check one):

Ministerial (Sec. 21080(b)(1); 15268);

Declared Emergency (Sec. 21080(b)(3); 15269(a));

Emergency Project (Sec. 21080(b)(4); 15269(b)(c));

Categorical Exemption. State type and section number: Sec.15302 (Class 2)

Statutory Exemptions. State code number: _____

Reasons why project is exempt:

The project is exempt under Section 15302 (Class 2 exemption) for the reason that it entails the replacement or reconstruction of existing structures and facilities where the new structure will be located on the same site as the structure replaced and will have substantially the same purpose and capacity as the structure replaced, this exemption includes but is not limited to the replacement or reconstruction of existing utility systems and/or facilities involving negligible or no expansion of capacity.

Lead Agency

Contact Person: Donald Vargas

Area Code/Telephone/Extension: (760) 482-3609

If filed by applicant:

1. Attach certified document of exemption finding.

2. Has a Notice of Exemption been filed by the public agency approving the project? Yes No

Signature: Vargas, Donald Digitally signed by Vargas, Donald
Date: 2025.05.20 13:12:41 -07'00'

Date: _____

Title: Compliance Administrator II

Signed by Lead Agency Signed by Applicant

Authority cited: Sections 21083 and 21110, Public Resources Code.

Reference: Sections 21108, 21152, and 21152.1, Public Resources Code.

Date Received for filing at OPR: _____