

NOTICE OF DETERMINATION

TO: Office of Land Use and Climate Innovation
State Clearinghouse
1400 Tenth Street, Room 113
Sacramento, CA 95812

FROM: State Water Resources
Control Board
500 North Central Avenue, Suite 500
Glendale, CA 91203
Contact: Dmitriy Ginzburg
Phone: (818) 551 -2022

Lead Agency: Paramount, City of
Lead Agency Contact: Adriana Figueroa
Lead Agency Phone: (562) 220-2100

SUBJECT: Filing of Notice of Determination in compliance with Section 21108 of the Public Resources Code.

Project Title: Water Well Facilities Improvement Project, Garfield Ave. Water Supply Permit Amendment (Project)

Project Applicant: Paramount - City, Water Department

Project Location: 16317 Garfield Avenue, Paramount, CA 90723, Los Angeles County

Project Description: The Applicant proposes operating Garfield Avenue Well 16 and a 3,400 gallon per minute, 70-80 psi groundwater treatment facility. The treatment process will reduce arsenic and manganese levels to meet the primary and secondary contaminant levels established by the USEPA and the California Division of Drinking Water. Additionally, a treatment goal is established to target reduction of arsenic below 80% of the primary MCL, or 8 ug/L.

This is to advise that the State Water Resources Control Board (Responsible Agency) has approved the above-described Project on 8/12/2025 and has made the following determinations regarding the above-described Project:

1. The Project will not have a significant effect on the environment. This determination is limited to the effects within the State Water Board's permitting jurisdiction as a Responsible Agency.
2. A Mitigated Negative Declaration was prepared for this Project pursuant to the provisions of CEQA.
3. Mitigation measures were not made a condition of the State Water Board's approval of the Project.
4. A mitigation monitoring and reporting plan/program was not adopted by the State Water Board for the Project.

A record of permit approval is available to the public upon request at the State Water Board, DDW office listed above. The Negative Declaration/Mitigated Negative Declaration is available from the Lead Agency.

A handwritten signature in blue ink, appearing to read "Dmitry Arz", is positioned above a solid black horizontal line.

Signature
District Engineer