

NOTICE OF EXEMPTION

TO:

Governor's Office of Land Use and Climate
Innovation
State Clearinghouse
1400 Tenth Street, Room 113
Sacramento, CA 95812

FROM:

State Water Resources Control Board
Division of Drinking Water (DDW)
1 Lower Ragsdale Dr., Bldg. 1, STE
120, Monterey, CA, 93940
Jonathan Weininger
Phone: (831) 655-6939

Project Applicant: California Water Service Company - Oak Hills

Project Title: Operation of Cal Water Service Co. SLN 205 – Hexavalent Chromium Treatment (Project)

Project Location: 9939 Pampas Path, Oak Hills, 93907, APN: 133-481-054-000

Project County: Monterey

Project Description: The Applicant is proposing to operate two non-regenerable ion exchange resin, pre-filters, and a post treatment disinfection system to treat groundwater from Well 01. Spent media will be sampled regularly and disposed of per regulations.

Public Agency Approving the Project: State Water Resources Control Board (State Water Board)

This is to advise that the State Water Board has issued a domestic water supply permit amendment for the above-described Project on 8/20/2025. A record of approval for the Project is available to the public at the State Water Board, Division of Drinking Water district office listed above.

CATEGORICAL EXEMPTION STATUS: Class 1: Existing Facilities Cal. Code of Regs., section 15301

Reason Why the Project Is Exempt: The Project is exempt because it is a minor alteration to an existing water system and there will be no change in use. None of the exceptions listed in section 15300.2 of the CEQA Guidelines would apply to the proposed Project.

Senior Environmental Scientist