

Notice of Exemption

To: ☒ Office of Planning and Research
P.O. Box 3044, Room 212
Sacramento, CA. 95812-3044

From: S.F. Bay Regional Water Quality Control Board
1515 Clay Street, Suite 1400
Oakland, CA 94612

☐ County Clerk

Project Title: East Vineyard Storm Drain Outfalls Repair Project

Project Location-Specific: Latitude 37.659462; longitude -121.826214; Vineyard Avenue and Safreno Way

Project Location-City: Pleasanton Project Location-County: Alameda

a) Description of Nature, Purpose and Beneficiaries of Project: The Project will replace a failed 24-inch diameter reinforced concrete pipe storm drain outfall to an unnamed tributary to Arroyo Del Valle, just north of Vineyard Avenue. The failed outfall was undermined by significant incision of the creek channel. The Project will also lay back the bank of the incised channel to a stable slope.

b) Name of Public Agency Approving Project: San Francisco Bay Regional Water Quality Control Board

Name of Person or Agency Carrying Out Project: City of Pleasanton

Exempt Status: (check one)

- ☐ Ministerial (Sec. 21080(b)(1); 15268);
☐ Declared Emergency (Sec.2108(b)(3); 15269(a);
☐ Emergency Project (Sec.21080(b)(4); 15269(b)(c);
☒ Categorical Exemption. State type and section number: Class I, California Code of Regulations (CCR) Title 14, Chapter 3 (CEQA Guidelines), § 15301 for the operation, repair, maintenance, permitting, leasing, licensing, or minor alteration of existing public or private structures, facilities, mechanical equipment, or topographical features, involving negligible or no expansion of use beyond that existing at the time of the lead agency's determination.
☐ Statutory Exemptions. State code number: State of California Public Resources Code (PRC) §21080(b)(10) and CEQA Guidelines §15275

Reasons why project is exempt:

The project involves the replacement of a failed stormwater outfall. The new outfall will have the same conveyance capacity as the failed outfall and will be constructed as close as possible to the location of the failed outfall.

Lead Agency

Contact Person: Brian Wines Area Code/Telephone/Extension: (510) 622-5680

If filed by applicant:

1. Attach certified document of exemption finding.
2. Has a Notice of Exemption been filed by the public agency approving the project: ☐ Yes ☐ No

Signature: Brian K. Wines Date: 9/20/2025 Title: Water Resource Control Engineer

☒ Signed by Lead Agency

Date received for filing at OPR: _____

☐ Signed by Applicant