NOTICE OF EXEMPTION

TO: ☒ Office of Planning and Research
State Clearinghouse
1400 Tenth Street
Sacramento, CA 95814

☒ County Clerk
County of Sonoma
585 Fiscal Drive, Room 103
Santa Rosa, CA 95403

FROM (Public Agency)**:**
Sonoma County Water Agency
404 Aviation Blvd.
Santa Rosa, CA 95403

Project Title: Wilfred Booster Station Electrical Upgrade Project

Project Location Specific: 4890 Commerce Blvd, Rohnert Park, CA 94928

Project Location – City: Rohnert Park **Project Location – County:** Sonoma

Description of Nature, Purpose and Beneficiaries of Project: The proposed project would upgrade the existing electrical system at the Wilfred Booster Pump Station, built in 1969, that conveys potable water through the Petaluma Aqueduct (pipeline). The upgrades would consist of replacing the existing 250 square-foot electrical building with a 550 square-foot building to accommodate current PG&E metering and safety requirements, providing a portable generator connection box motor valve actuators, and installing a 200 square-foot storage shed on an existing concrete pad. Construction would require minor grading and trenching in areas previously developed at the Wilfred Station. Also, trees along the border of the Station may be trimmed, but not removed. These upgrades would not change the pumping capacity of the Station.

Lead Agency Approving Project: Sonoma County Water Agency

Lead Agency Contact Name and Phone: David Cook 707-322-8176

Applicant: Sonoma County Water Agency

Applicant Contact Name and Phone: David Cook 707-322-8176

Exempt Status (check one):

☐ Ministerial (Sec. 21080(b)(1); 15268);
☐ Declared Emergency (Sec. 21080(b)(3); 15269(a));
☐ Emergency Project (Sec.21080 (b)(4); 15269(b)(c));
☒ Categorical Exemption. State type and section number: CEQA Guidelines §15301, Existing Facilities; §15302, Replacement or Reconstruction; and §15304, Minor Alterations to Land
☐ Statutory Exemptions. State Code number:

Reasons why project is exempt: The project is exempt because the replacement and upgrade of existing facilities would involve no expansion of use, and would not remove healthy, mature, or scenic trees.

Signature	Title	Date
Kent Gylfe for	General Manager	December 9, 2025

☒ Signed by Lead Agency Approving the Project Date received for filing at OPR:_____