

111 N. HOPE STREET, ROOM 1044

LOS ANGELES, CALIFORNIA 90012

CALIFORNIA ENVIRONMENTAL QUALITY ACT

NOTICE OF EXEMPTION

(City CEQA Guidelines)

Submission of this form is optional. The form shall be filed with the County Clerk, pursuant to Public Resources Code Section 21152(b). Pursuant to Public Resources Code Section 21168(d), the filing of this notice starts a 35-day statute of limitations on Court challenges to the approval of the project. Failure to file the notice results in the statute of limitations being extended to 180 days.

LEAD AGENCY/ APPLICANT AND ADDRESS: Los Angeles Department of Water and Power (LADWP) 111 N. Hope Street, Room 1044 Los Angeles, CA 90012	COUNCIL DISTRICT 13 – Soto-Martinez
---	---

PROJECT TITLE Edenhurst Ave On-Ramp Interchange Guy Power Pole Replacement	LOG REFERENCE N/A
--	-----------------------------

PROJECT LOCATION
On-Ramp Interchange at Edenhurst Ave/Colorado St. Freeway Exit. See attached Map.


DESCRIPTION OF NATURE, PURPOSE, AND BENEFICIARIES OF PROJECT:
The Los Angeles Department of Water and Power (LADWP) is proposing to replace a guy power pole that was struck and downed in the Caltrans Right-of-Way at the on-ramp interchange at the Edenhurst Ave./Colorado St. freeway exit. LADWP will use a digger derrick, bucket truck, and foreman truck to dig an approximately 6.5 feet deep and 13-inch diameter hole, and set the new 45-foot tall pole. The guy power pole is required to provide structural support for existing power distribution infrastructure in the area. All equipment will be staged on sparsely vegetated areas within the right-of-way, and will not require vegetation removal.

CONTACT PERSON James R. Howe	AREA CODE 213	TELEPHONE NUMBER EXT. 367-0414
--	-------------------------	--


EXEMPT STATUS: (Check One)		
☐ MINISTERIAL	CITY CEQA GUIDELINES Art. II, Sec. 2b	STATE CEQA GUIDELINES Sec. 15268
☐ DECLARED EMERGENCY	Art. II, Sec. 2a(1)	Sec. 15269
☐ EMERGENCY PROJECT	Art. II, Sec. 2a(2) & (3)	Sec. 15071(b) & (c)
☐ GENERAL EXEMPTION	Art. II, Sec. 1	Sec. 15060
☒ CATEGORICAL EXEMPTION	Art. III, Sec. 1	Sec. 15300
☐ OTHER (See Public Resources Code Sec. 21080(b) and set forth state and city guidelines provision)		

JUSTIFICATION FOR PROJECT EXEMPTION:
In accordance with the California Environmental Quality Act, this project is Categorically Exempt from CEQA review pursuant to Section 15301, Class 1 and Section 15302, Class 2. Class 1 consists of the operation, repair, maintenance, permitting, leasing, licensing, or minor alteration of existing public or private structures, facilities, mechanical equipment, or topographical features, involving negligible or no expansion of the existing or former use. Class 2 consists of replacement or reconstruction of existing structures and facilities where the new structure will be located on the same site as the structure replaced and will have substantially the same purpose and capacity as the structure replaced.

IF FILED BY APPLICANT, ATTACH CERTIFIED DOCUMENT OF EXEMPTION FINDING

SIGNATURE  Jane Hauptman	TITLE: Manager of Environmental Planning and Assessment	DATE 01/20/2026
FEE: N/A	RECEIPT NO.	REC'D BY
		DATE

Project Location – Regional Map



Project Location – Vicinity Map

