

## NOTICE OF EXEMPTION

**TO:**

Governor's Office of Land Use and Climate  
Innovation  
State Clearinghouse  
1400 Tenth Street, Room 113  
Sacramento, CA 95812

**FROM:**

State Water Resources Control Board  
Division of Drinking Water (DDW)  
3021 Reynolds Ranch Pkwy, STE 260  
Lodi, CA 95240  
Bhupinder Sahota  
Phone: (209) 948-7696

**Project Applicant:** East Bay Municipal Utility District Camanche South Shore

**Project Title:** Camanche South Shore Water Treatment Plant Sulfuric Acid Feed System-Water Supply Permit Amendment (Project)

**Project Location:** Bret Harte Drive, Wallace, 38.220710, -120.924937

**Project County:** Calaveras

**Project Description:** The Applicant proposes to operate a 335-gallon sulfuric acid storage tank, pump skid, static mixer, and pH sensor for dosing sulfuric acid to the Camanche South Shore Water Treatment Plant raw water to control the pH.

**Public Agency Approving the Project:** State Water Resources Control Board (State Water Board)

This is to advise that the State Water Board has issued a domestic water supply permit amendment for the above-described Project on February 26, 2026. A record of permit approval for the Project is available to the public at the State Water Board, Division of Drinking Water district office listed above.

**CATEGORICAL EXEMPTION STATUS: Class 1: Existing Facilities** Cal. Code of Regs., section 15301

**Reason Why the Project Is Exempt:** The Project is exempt because it is the minor modification and operation of an existing water treatment system with no change in use. None of the exceptions listed in section 15300.2 of the CEQA Guidelines would apply to the proposed Project.

*Adrian Dela Calzada*

Date: February 27, 2026

Adrian Dela Calzada  
Environmental Scientist