

Summary Form for Electronic Document Submittal

Form F

Lead agencies may include 15 hardcopies of this document when submitting electronic copies of Environmental Impact Reports, Negative Declarations, Mitigated Negative Declarations, or Notices of Preparation to the State Clearinghouse (SCH). The SCH also accepts other summaries, such as EIR Executive Summaries prepared pursuant to CEQA Guidelines Section 15123. Please include one copy of the Notice of Completion Form (NOC) with your submission and attach the summary to each electronic copy of the document.

SCH #: _____

Project Title: Carillion Water Treatment Plant Deep Well Project

Lead Agency: City of Galt, Public Works Department

Contact Name: Alejandra Ricci

Email: aricci@cityofgalt.org Phone Number: (209) 366-7260

Project Location: Galt, Sacramento County
City County

Project Description (Proposed actions, location, and/or consequences).

The City of Galt Public Works Department plans to replace Well 16 within the Carillion Water Treatment Plant (WTP) and target a new aquifer. The existing well would be destroyed. The Carillion WTP has two wells, River Oaks Well and Well 16, both of which undergo a chlorine and chemical treatment process for arsenic, iron, and manganese removal in raw water. Upgrades to the water treatment system would occur. These upgrades would include construction of a production well, booster pump station, and storage tank. A permanent test well will also be placed for future well replacement needs.

The Project area is a flat 1.4-acre parcel with a water treatment system located at the western end and an open grassy area extending across the eastern portion of the parcel. Landscape trees are present, some of which would be removed for the construction of a new driveway connecting to the street. Trenching through landscaped areas will be completed for new drainage and piping to Di Maggio Boulevard. Modifying and/or moving existing irrigation is also planned. Surface grading would be done to improve drainage to storm drain inlets. At the grassy unimproved eastern portion of the site there would be installation of a new 1.5 MG tank, gravel at the location of a second future 1.5 MG tank, a concrete vault, underground piping and conduits, a booster pump station extending below ground, and pavement at all unpaved areas.

Identify the project's significant or potentially significant effects and briefly describe any proposed mitigation measures that would reduce or avoid that effect.

No significant or potentially significant impacts were identified within the CEQA document and no mitigation is required for the project.

If applicable, describe any of the project's areas of controversy known to the Lead Agency, including issues raised by agencies and the public.

Not Applicable.

Provide a list of the responsible or trustee agencies for the project.

No responsible or trustee agencies have been identified to date.