



CITY OF MANTECA

Engineering Department

April 21, 2026

TO: Responsible Agencies, Interested Parties, and Organizations

SUBJECT: **City of Manteca Central Trunk Sewer Project – City of Manteca**

The City of Manteca (City) is the California Environmental Quality Act (CEQA) Lead Agency for the proposed City of Manteca Central Trunk Sewer Project (Proposed Project). The City has directed the preparation of an Initial Study/Mitigated Negative Declaration (IS/MND) in compliance with CEQA.

Project Location: The City of Manteca Central Trunk Sewer Project (Project) Area consists of an area approximately 0.8 mile in length and 40 feet wide for the proposed new segment of sewer line within the City. The Project Site is located within Section 31, Township 1 South, Range 7 East, Mount Diablo Base and Meridian, as depicted on the 1994 minor revised edition of the 1980 photorevised edition of the 1952 U.S. Geological Survey Manteca, California 7.5-minute quadrangle.

Project Description: The Central Trunk Sewer Replacement Project (Project) consists of the replacement of an existing 36-inch diameter sanitary sewer trunk line that is deteriorated and aged connecting to the Union Road Lift Station (URLS) located within the Parks Department Corporation Yard. The new 36-inch trunk sewer line will be approximately 4,300 LF of 36-inch PVC SDR 26 pipe. The existing lifting station will be decommissioned in the future by others. The new sewer line will begin downstream near the newly constructed subdivision off the Airport Road and extend eastward through the Kaiser Development, crossing the canal, through the Manteca Park Golf Course, continuing under the Parks Department Corp Yard and tie-in to the URLS at an existing sewer manhole.

Findings/Determination: They City of Manteca has reviewed and considered the proposed project and has determined that the project will not have a significant effect on the environment with the incorporation of mitigation measures, as supported by evidence provided in the Initial Study. The City of Manteca hereby prepares and proposes to adopt a Mitigated Negative Declaration for this project.

IS/MND Document Review and Availability: The public review and comment period for the Draft IS/MND will extend for 30 days starting **April 24, 2026** and ending **May 25, 2026**. Draft IS/MND can be viewed and/or downloaded at the following website:

<https://www.manteca.gov/departments/development-services/planning/planning-documents/environmental-documents-notice>

Comments/Questions: Comments and/or questions regarding the IS/MND may be directed to:

City of Manteca Engineering Department
Attn: Alfredo Mijango, Associate Engineer
1001 West Center Drive
Manteca, CA 95337
or
amijango@manteca.gov