

CENTRAL VALLEY FLOOD PROTECTION BOARD

3310 El Camino Ave., Ste. 170
SACRAMENTO, CA 95821
(916) 574-0609



May 29, 2026

Sarah Ahmed
SMUD Environmental Services
P.O. Box 15830 MS B209
Sacramento, CA 95852-1830
Sarah.Ahmed@smud.org

Subject: Comments for the Draft Initial Study and Mitigated Negative Declaration, Jackson Bulk Substation Project, SCH# 2026050302, Sacramento County

Dear Sarah Ahmed,

The Central Valley Flood Protection Board (Board) appreciates the opportunity to comment on the Draft Initial Study and Mitigated Negative Declaration (IS/MND) for the proposed Jackson Bulk Substation Project (proposed project).

The proposed project involves upgrading existing overhead lines crossing Elder Creek and Morrison Creek, both of which are regulated streams within the Board's permitting authority. Therefore, a Board permit may be required. Board permit information, including information on how to schedule a pre-application meeting with Board staff, is available on the [Permitting at the Central Valley Flood Protection Board website](#).

Please include the Central Valley Flood Protection Board permit regulatory setting under heading 2.6 Potential Permits and Approvals Required.

Responsibility of the Board

The Board is the State's regulatory agency responsible for enforcing appropriate standards for the construction, maintenance, and operation of the flood control system that protects life, property, and habitat in California's Central Valley.

The Board operates under authorities as described in California Water Code (Water Code), which requires the Board to oversee future modifications or additions to facilities of the State Plan of Flood Control (SPFC).

Board Permit

Per Title 23, Section 6, approval by the Board is required for all proposed work or uses, including the alteration of levees within any area for which there is an Adopted Plan of Flood Control within the Board's jurisdiction. In addition, Board approval is required for all proposed encroachments within a floodway, on adjacent levees, and within any Regulated Stream identified in Title 23, Table 8.1. Specifically, Board jurisdiction includes the levee section, the waterward area between project levees, a minimum 10-foot-wide strip adjacent to the landward levee toe, the area within 30 feet from the top of bank(s) of Regulated Streams, and inside the

SMUD Environmental Services

May 29, 2026

Page 2

Board's Designated Floodways. Activities outside of these limits which could adversely affect Federal-State flood control facilities, as determined by the Board, are also under the Board's jurisdiction. Permits may also be required for existing unpermitted encroachments or where it is necessary to establish the conditions normally imposed by permitting, including where responsibility for the encroachment has not been clearly established or ownership or uses have been changed.

Flood Impacts Analysis

Pursuant to Title 23, Section 15, the Board may deny a Board permit if the proposed project could:

- Jeopardize directly or indirectly the physical integrity of levees or other works,
- Obstruct, divert, redirect, or raise the surface level of design floods or flows, or the lesser flows for which protection is provided,
- Cause significant adverse changes in water velocity or flow regimen,
- Impair the inspection of floodways or project works,
- Interfere with the maintenance of floodways or project works,
- Interfere with the ability to engage in flood fighting, patrolling, or other flood emergency activities,
- Increase the damaging effects of flood flows,
- Be injurious to, or interfere with, the successful execution, functioning, or operation of any adopted plan of flood control, or
- Adversely affect the State Plan of Flood Control, as defined in the California Water Code

The Board, as a Responsible Agency under the California Environmental Quality Act (CEQA), will review and consider the environmental effects of the proposed project identified in the IS/MND, and will reach its own conclusions on whether and how to approve the project involved (14 CCR 15096, subd. (a)). This includes direct impacts to facilities under construction, as well as indirect impacts from the proposed project to surrounding facilities. Accordingly, the comments herein are intended to assist in the development of a robust CEQA document capable of supporting the Board's permitting process.

Closing

The potential risks to public safety, including increased flood risks, need to be considered when developing proposed projects that seek to modify flood control works or the hydrology of the water ways. Board staff is available to discuss any questions you have regarding the above comments. Please contact Jordan Robbins at (916) 524-3454, or via email at Jordan.Robbins@CVFlood.ca.gov if you have any questions.

Sincerely,

Jamie Silva

Jamie Silva
Environmental Program Manager

SMUD Environmental Services

May 29, 2026

Page 3

cc: Office of Land Use and Climate Innovation
State.Clearinghouse@lci.ca.gov

Steve Lamb
Permitting Section Manager
Steve.Lamb@cvflood.ca.gov