

## NOTICE OF EXEMPTION

**TO:**

Governor's Office of Land Use and Climate  
Innovation  
State Clearinghouse  
1400 Tenth Street, Room 113  
Sacramento, CA 95812

**FROM:**

State Water Resources Control Board  
Division of Drinking Water (DDW)  
2375 Northside Dr., STE 100  
San Diego, CA, 92108  
Aaron Kent  
Phone: (619) 525-4159

**Project Applicant:** Jacumba Chevron and Shell System (Applicant)

**Project Title:** Jacumba Chevron and Shell System Water Supply Permit (Project).

**Project Location:** 1494 Carrizo Gorge Road, Jacumba, 91934, APN 661-010-28

**Project County:** San Diego

**Project Description:**

The Applicant proposes installing a new water pump, four 85-gallon pressure tanks, reconfiguring existing water system piping, and operating as a new public water system. The Applicant has chosen to establish a public water system under new ownership. Although the existing facility historically relied on Well 01 from the Jacumba Valley Ranch Water Company, the facility began purchasing hauled water from a certified hauling company and disconnected from Well 01 on March 14, 2026. The Applicant currently relies solely on hauled water.

**Public Agency Approving the Project:** State Water Resources Control Board (State Water Board)

This is to advise that the State Water Board has issued a domestic water supply permit for the above-described Project on May 21, 2026. A record of approval for the Project is available to the general public at the State Water Board, Division of Drinking Water district office listed above.

**CATEGORICAL EXEMPTION STATUS: Class 1: Existing Facilities** Cal. Code of Regs., section 15301

**Reason Why the Project Is Exempt:** The Project is exempt because it is a small alteration to an existing water system and there will be no change in use. None of the exceptions listed in section 15300.2 of the CEQA Guidelines would apply to the proposed Project.

---

Senior Environmental Scientist