

NOTICE OF EXEMPTION

TO:

Governor's Office of Land Use and Climate
Innovation
State Clearinghouse
1400 Tenth Street, Room 113
Sacramento, CA 95812

FROM:

State Water Resources Control Board
Division of Drinking Water (DDW)
1001 I ST, 19TH Floor
Sacramento, CA 95814
Austin Peterson
Phone: (916) 449-5681

Project Applicant: California American Water Co. – Antelope

Project Title: Fox Park Well Hexavalent Chromium Treatment-Water Supply Permit Amendment (Project)

Project Location: 8623 Fox Park Ct. and Redwater Dr., 38.7261434290869, -121.38497204965655, APN: 203-0060-086-0000

Project County: Sacramento

Project Description: The Applicant proposes installation and operation of a skid mounted strong base ion exchange treatment system for removal of hexavalent chromium from the drinking water at the Fox Park Court Well. The proposed treatment will be used in conjunction with the existing well and chlorination system.

Public Agency Approving the Project: State Water Resources Control Board (State Water Board)

This is to advise that the State Water Board has issued a domestic water supply permit amendment for the above-described Project on August 13, 2026. A record of permit approval for the Project is available to the public at the State Water Board, Division of Drinking Water district office listed above.

CATEGORICAL EXEMPTION STATUS:

Class 1: Existing Facilities Cal. Code of Regs., section 15301

Reason Why the Project Is Exempt: The Project is exempt because it is the installation and operation of health protection devices at an existing public water facility with no change in use. None of the exceptions listed in section 15300.2 of the CEQA Guidelines would apply to the proposed Project.

 Digitally signed by Wendy
Pierce
Date: 2026.08.13 14:49:14
Water Resources

Senior Environmental Scientist