NOTICE OF EXEMPTION

TO:
Governor's Office of Land Use and Climate Innovation
State Clearinghouse
1400 Tenth Street, Room 113
Sacramento, CA 95812

FROM:
State Water Resources Control Board
Division of Drinking Water (DDW)
500 North Central Ave. STE. 500,
Glendale, CA 91203
Bill Liang
Phone: (818) 551-2004

Project Applicant: California Water Service Co. Dominguez

Project Title: Operation of California Water Service Dom Wells 215 & 216 Treatment-Water Supply Permit Amendment (Project)

Project Location: 21718 Alameda St. Carson, 90810, APN 731-601-30-10

Project County: Los Angeles

Project Description: The Applicant proposes to operate breakpoint reaction vessels in conjunction with chloramination treatment to increase chlorine contact time for disinfection. The improvements to the existing water system were installed under a City of Carson ministerial permit.

Public Agency Approving the Project: State Water Resources Control Board (State Water Board)

This is to advise that the State Water Board has issued a domestic water supply permit amendment for the above-described Project on October 8, 2026. A record of permit approval for the Project is available to the public at the State Water Board, Division of Drinking Water district office listed above.

CATEGORICAL EXEMPTION STATUS:

Class 1: Existing Facilities Cal. Code of Regs., section 15301

Reason Why the Project Is Exempt: The Project is exempt because it is the operation of a minor modification to an existing public water system with no change in use. None of the exceptions listed in section 15300.2 of the CEQA Guidelines would apply to the proposed Project.

Wendy Pierce Digitally signed by Wendy Pierce
Date: 2026.10.12 11:15:10 -07'00'
Water Boards

Senior Environmental Scientist

Authority cited: Sections 21083 and 21110, Public Resources Code. Reference: Sections 21108, 21152, and 21152.1, Public Resources Code.